From: planning@adur-worthing.gov.uk
Sent: 22 July 2022 13:27
To: planning@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/1232/22

Flag Status: Flagged

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 22/07/2022 1:27 PM from Mrs Hannah Powell (hannah.powell@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/1232/22
Address:	66 Old Fort Road Shoreham-by-sea West Sussex BN43 5HA
Proposal:	Approval of Details Reserved by Condition 3 (noise attenuation scheme) of AWDM/2199/21.
Case Officer:	Hannah Barker

Click for further information

Comments Details

Comments:	With reference to the above application, the specification of the ASHP has been provided together with confirmation that the unit will be mounted on anti-vibration mounts and will be maintained in accordance with the manufacturers guidance. This specification advises the sound pressure level of the unit will be 45dBA at 1m. I am satisfied that this noise level will not negatively affect the amenity of the neighbouring dwelling. Will there be any external plant associated with the swimming pool?

Kind regards