From: planning@adur-worthing.gov.uk
Sent: 26 May 2023 17:12
To: planning@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/0559/23

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 26/05/2023 5:12 PM from Mr Nadeem Shad (nadeem.shad@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0559/23
Address:	Land At 7 To 27 Albion Street Southwick West Sussex
Proposal:	Approval of Details Reserved by Conditions: Condition 13 (Air Quality Assessment) and Condition 19 (Details of Vehicle Access) of approved application AWDM/0954/18.
Case Officer:	Peter Barnett

Click for further information

Comments Details

Comments:	With respect to Condition 13, the Boiler Specification Sheet lists the selected boiler with a NOx weight (gross) of 34.9mg/kWh. If this is equivalent to the NOx emission rate (and the applicant should be asked to confirm this), then we have no further comments.

Kind regards