From: **Oliver Rochford**
Date: Fri, 6 Feb 2026 at 11:45
Subject: AWDM/1199/25
To: Louise Prew <louise.prew@adur-worthing.gov.uk>

Good Morning Louise,

Please see my comments below regarding my initial comments and the documents sent since they were made:

An Industrial Noise Impact Assessment for the Installation of New Plant (Ref:IMP7948-1, Dated: September 2025) was provided in support of the above application. The report concluded that the proposed plant equipment would have a "Low Impact" on the surrounding residential units providing that the mitigation measures listed in the above mentioned report were followed. As per my initial comments, a post completion test is required to demonstrate compliance.

The Industrial Noise Impact Assessment only relates to the plant equipment, a separate assessment is to be provided for the insulation scheme for the upper floor residential unit to achieve a minimum airborne sound insulation value of 50dB (DnTw + Ctr dB) for all floors. Again, a post completion test will be required.

In summary, my initial comments and recommendations remain the same, I am satisfied with the assessment for the extraction system however as mentioned above I require post completion testing before recommending its discharge/removal.

Kind Regards