Former EDF Car Park, Southdownview Road, Worthing, BN14 8NH
Planning Portal Ref: PP-13832952

Condition 32

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: Wednesday, February 19, 2025 1:05:45 PM
To: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Cc: Dan Withey <DWithey@connect-consultants.com>
Subject: Fire hydrant condition raised for AWDM/0056/22 Former Edf Car Park Southdownview Road Worthing West Sussex

FAO: Jo Morin

Dear Jo,

Following further information provided by Connect Consultants showing the location of a fire hydrant supplied by a 90mm main size on site, I am satisfied that, providing this fire hydrant is in place, ready for use, and WSFRS are informed it is ready for use, prior to any occupation of any of the units the fire hydrant condition will be met. Unfortunately, on too many occasions we are not informed it is ready for use which then puts lives and properties at a greater risk in the event of a fire.

Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 **Mobile** 07921 291051
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.