From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 18 March 2025 10:59:40 UTC+01:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Consultee Comments for Planning Application AWDM/0336/25

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 18/03/2025 9:59 AM from Mr Nadeem Shad (nadeem.shad@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0336/25
Address:	Land South West Of Pumping Station Basin Road South Southwick West Sussex
Proposal:	Approval of Details Reserved by Condition 5: Construction Environment Management Plan (CEMP) of application AWDM/0400/24.
Case Officer:	Peter Barnett

Click for further information

Comments Details

Comments:	Under Section 6 Noise, I recommend the hours of work be reduced to commence at 08:00 and finish by 18:00. Whilst some distance from residential property experience has shown that wind speed and direction can result in Port activities being easily audible at residential properties some distance away. Under Section 14 Routing of traffic I recommend any goods vehicle movements associated with the site follow the recommended lorry routes promoted by West Sussex County Council and Brighton & Hove CC and avoid nearby Air Quality Management Areas.

Kind regards