From: Peter Barnett
Sent: 02 October 2009 16:06
To: 'johnforplans@yahoo.co.uk'
Subject: ADC/0383/09 - 14 Abbots View, Sompting

Dear John

With reference to the above application, can you please confirm the overall depth of the extension? The elevations scale off as 4.8m but the floor plan scales as 4.3m, with the angled part of the conservatory coming at 3.5m.

Could you please correct the drawing and submit a revised plan?

Thanks

Peter

Peter Barnett **– Principal Planning Officer** | Planning Regeneration and Wellbeing, Adur District Council
Location: Civic Centre, Ham Road, Shoreham-by-Sea, West Sussex BN43 6PR
Internal: 63233 | External: 01273 263233 | E-mail: peter.barnett@adur.gov.uk

Please think before you print this and save paper