From: Richard Small <richard.small@adur-worthing.gov.uk> on behalf of Richard Small
Sent: 17 February 2021 13:11
To: Hannah Barker
Subject: Re: 25 John Street Shoreham AWDM/2082/20

Hi Hannah,

Looking at the drawings and photographs, the proposed extension appears to use the brick and cobbled wall of the listed building as part of a new wall construction. The Listed Building is likely to have a solid wall construction and will have a cycle of the walls absorbing water and then drying out. If the outside face of the wall is sealed into the new wall construction, then any moisture in this part of the wall is likely to migrate into the listed building. This could therefore potentially harm the listed building.

Kind regards
Richard

On Mon, 8 Feb 2021 at 15:51, Hannah Barker <hannah.barker@adur-worthing.gov.uk> wrote:

> Hi Richard,
>
> Hope you are well, please could you take a look at this one for me. Details on Info@work and I will forward some photos.
>
> It's a single storey rear extension which abuts the Grade II listed building at no. 23 and is in the Cons Area.
>
> I don't think it's harmful however please could I have your views?
>
> Thanks
> Hannah
>
> **Hannah Barker**
> Senior Planning Officer, Adur & Worthing Councils
> Phone: 01903 221475
> Email: hannah.barker@adur-worthing.gov.uk
> Website: http://www.adur-worthing.gov.uk
> Portland House
> Richmond Road
> Worthing
> West Sussex
> BN11 1HH

--

Richard Small

Email: richard.small@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



