From:	Graham, Martin <martin.graham@ukpowernetworks.co.uk> on behalf of MBX-Consents Enquiries
Sent:	02 October 2023 11:10
To:	Planning -
Subject:	FW: Planning Application Consultation for Former Garage Block 123 To 139 Wilmot Road Shoreham-by-sea West Sussex
Attachments:	ufm3_Standard_Consultation_Letter_-_External.rtf
Flag Status:	Flagged

Dear Sirs

We refer to the Planning Application for the above site. The proposed development is in close proximity to our substation and have the following observations to make:

If the proposed works are located within 6m of the substation, then they are notifiable under the Party Wall etc. Act 1996. The Applicant should provide details of the proposed works and liaise with the Company to ensure that appropriate protective measures and mitigation solutions are agreed in accordance with the Act. The Applicant would need to be responsible for any costs associated with any appropriate measures required. Any Party Wall Notice should be served on UK Power Networks at its registered office: UK Power Networks, Newington House, 237 Southwark Bridge Road, London SE1 6NP.

Our engineering guidelines state that the distance between a dwelling of two or more stories with living or bedroom windows overlooking a distribution substation should be a minimum of ten metres if the transformer is outdoor, seven metres if the transformer has a GRP surround or one metre if the transformer is enclosed in a brick building. It is a recognised fact that transformers emit a low level hum which can cause annoyance to nearby properties. This noise is mainly airborne in origin and is more noticeable during the summer months when people tend to spend more time in their gardens and sleep with open windows.

A problem can also occur when footings of buildings are too close to substation structures. Vibration from the transformer can be transmitted through the ground and into the walls of adjacent buildings. This, you can imagine, is very annoying.

In practice there is little that can be done to alleviate these problems after the event. We therefore offer advice as follows:

1. The distance between buildings and substations should be greater than seven metres or as far as is practically possible.

2. Care should be taken to ensure that footings of new buildings are kept separated from substation structures.

3. Buildings should be designed so that rooms of high occupancy, i.e. bedrooms and living rooms, do not overlook or have windows opening out over the substation.

4. If noise attenuation methods are found to be necessary we would expect to recover our costs from the developer.

Other points to note:

5. UK Power Networks require 24 hour vehicular access to their substations. Consideration for this should be taken during the design stage of the development.

6. The development may have a detrimental impact on our rights of access to and from the substation. If in doubt please seek advice from our Operational Property and Consents team at Barton Road, Bury St Edmunds, Suffolk, IP32 7BG.

7. No building materials should be left in a position where they might compromise the security of the substation or could be used as climbing aids to get over the substation surround.

8. There are underground cables on the site associated with the substation and these run in close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.

9. All works should be undertaken with due regard to Health & Safety Guidance notes HS(G)47 Avoiding Danger from Underground services. This document is available from local HSE offices.

Should any diversion works be necessary as a result of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.

Regards

Martin Graham
Business Support
Property and Consents Team at UK Power Networks

Please note that I do not routinely work on Fridays

M: 03301591841
martin.graham@ukpowernetworks.co.uk
ukpowernetworks.co.uk
Barton Road, Bury St Edmunds, Suffolk, IP32 7BG

-----Original Message-----
From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: Friday, September 29, 2023 10:52 AM
To: MBX-Consents Enquiries <consents@ukpowernetworks.co.uk>
Subject: Planning Application Consultation for Former Garage Block 123 To 139 Wilmot Road Shoreham-by-sea West Sussex

[External]: Please note this email has been sent to you by an external source. Please use caution when clicking on links or attachments.

Please see attached planning consultation

This email and any attachments are strictly confidential and may contain legally privileged information or personal data. It is intended for the addressee(s) only. If you are not the intended recipient, please do not print, copy, store, or act in reliance on the e-mail or any of its attachments. Instead, please notify the sender immediately and then delete the e-mail and any attachments.

Unless expressly stated to the contrary, the opinions expressed in this e-mail are not necessarily the opinions of UK Power Networks Holdings Limited or those of its subsidiaries or affiliates (together Group Companies) and the Group Companies, their directors, officers and employees make no representation and accept no liability for the accuracy or completeness of this e-mail or its attachments.

This e-mail has been scanned for malicious content but the Group Companies cannot accept any liability for the integrity of this message or its attachments. No employee or agent of the Group Companies is authorised to conclude any binding agreement on behalf of a Group Company or any related company by e-mail.

All e-mails sent and received by any Group Company are monitored to ensure compliance with the Group Companies information security policy. Executable and script files are not permitted through the mail gateway of UK Power Networks Holdings Limited. The Group Companies do not accept or send emails above 30 Mb in size.

UK Power Networks Holdings Limited Registered in England and Wales No. 7290590. Registered Office: Newington House, 237 Southwark Bridge Road, London SE1

ADUR & WORTHING
COUNCILS

South East Power Networks PLC

Our reference:	AWDM/1357/23
Please ask for:	Gary Peck
Direct Line:	01903 221406
Date:	29th September 2023

Dear Sir/Madam,

Approval of Details Reserved by Conditions 7 (Electric vehicle charging spaces) and 16 (Refuse storage) of AWDM/1434/21.

Former Garage Block 123 To 139 Wilmot Road Shoreham-by-sea West Sussex

The above planning application was received on 28th September 2023. Please may I have your observations on the above mentioned planning application within the next 21 days.

To view the application please click on the link below or copy and paste into the web browser. Applications can take up to 5 working days to appear. http://planning.adur-worthing.gov.uk/online-applications/

Yours faithfully

Gary Peck
Planning Services Manager

Adur & Worthing Councils, Development Management, Economy Directorate,
Portland House, 44 Richmond Road, Worthing, West Sussex, BN11 1HS
Tel: 01903 221065 Email: planning@adur-worthing.gov.uk
Web: www.adur-worthing.gov.uk