On Tue, 7 May 2024 at 15:28, FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk> wrote:

Afternoon Stephen, Rolland,

That is exactly what we were looking for, showing the distance from fire hydrant to fire appliance and fire appliance to the dry riser inlet, all of which show to be within the required distances.

I am satisfied the condition has been met.

Regards

Ian