creating a better place
for people and wildlife

Environment Agency

Adur & Worthing Councils
Planning team
Portland House
Richmond Road
Worthing
West Sussex
BN11 1LF

Our ref: HA/2023/125213/02
Your ref: AWDM/0666/23

Date: 16 August 2023

Dear Planning team (FAO: Marie O'Keeffe)

CHANGE OF USE TO CONVERT THE FIRST, SECOND AND THIRD FLOORS TO RESIDENTIAL TO CREATE A FOUR BEDROOM FLAT.

5 BATH PLACE, WORTHING, WEST SUSSEX, BN11 3BA.

Thank you for consulting the Environment Agency on the above application following the submission of a revised Flood Risk Assessment.

We have reviewed the information as submitted and set out our position and comments below.

Environment Agency position

We are satisfied that our previous objection (as per our letter dated 19 July 2023) can be removed provided that the following condition be attached to any planning permission granted, and that the details in relation to the condition be submitted and approved by the Local Planning Authority.

Condition – Flood risk

The development shall be carried out in accordance with the submitted flood risk assessment (dated August 2023) and the following mitigation measures it details:

- **All sleeping accommodation shall be at or above First Floor level.**

These mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements.

The measures detailed above shall be retained and maintained thereafter throughout the lifetime of the development.

Reasons

Cont/d..

To reduce the risk of flooding to the proposed development and future occupants.

The condition is in line with the Planning Practice Guidance (PPG) to the National Planning Policy Framework (NPPF) for Flood Risk and Coastal Change.

Please notify us immediately if you are unable to apply our suggested condition to allow further consideration and advice.

Advice to the Local Planning Authority

Flood warning and emergency response

We do not normally comment on or approve the adequacy of flood emergency response procedures accompanying development proposals, as we do not carry out these roles during a flood. Our involvement with this development during an emergency will be limited to delivering flood warnings to occupants/users covered by our flood warning network.

The Planning Practice Guidance (PPG) to the National Planning Policy Framework states that, in determining whether a development is safe, the ability of residents and users to safely access and exit a building during a design flood and to evacuate before an extreme flood needs to be considered. One of the key considerations to ensure that any new development is safe is whether adequate flood warnings would be available to people using the development.

In all circumstances where warning and emergency response is fundamental to managing flood risk, we advise local planning authorities to formally consider the emergency planning and rescue implications of new development in making their decisions. As such, we recommend you refer to 'Flood risk emergency plans for new development' and undertake appropriate consultation with your emergency planners and the emergency services to determine whether the proposals are safe in accordance with paragraph 163 of the NPPF and the guiding principles of the PPG.

If you have any queries regarding the above information, please do not hesitate to contact the advisor identified below.

Yours faithfully,

Environment Agency – Solent & South Downs

Sustainable Places Advisor: Anna Rabone
Direct dial: 02077 140525
Direct e-mail: anna.rabone@environment-agency.gov.uk

End