From: Gary Peck <gary.peck@adur-worthing.gov.uk> on behalf of Gary Peck
Sent: 28 February 2023 17:24
To: Planning -
Subject: Fwd: AWDM/0219/23

---------- Forwarded message ---------
From: **Nadeem Shad** <nadeem.shad@adur-worthing.gov.uk>
Date: Tue, 28 Feb 2023 at 17:22
Subject: AWDM/0219/23
To: Gary Peck <gary.peck@adur-worthing.gov.uk>

AWDM/0219/23

6 Old Shoreham Road Lancing West Sussex BN15 0QT

I refer to the above application and the Construction Management Plan submitted as part of Condition 6 of AWDM/1802/19.

The hours of work on Saturdays need revising to 09:00.

The dust section contains nothing on water suppression. There is reference to constant surveillance and not causing nuisance to neighbours. I suggest the target should be to avoid dust being allowed to escape the site boundary.

There is reference to Piling. Is piling taking place on this site?

Once these have been addressed I can comment further.

Thanks
Nadeem

Nadeem Shad (he/him)
Team Leader Environmental Protection, Public Health & Regulation
01273 263303
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
http://www.adur-worthing.gov.uk/environmental-health/





--

Gary Peck
Planning Services Manager, Planning & Development
1903221406
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
http://www.adur-worthing.gov.uk

