Re: AWDM/0399/24 6 Windsor Road Worthing

1 message

David Starr <david.starr@adur-worthing.gov.uk> 5 June 2024 at 09:57
To: Rebekah Smith <rebekah.hincke@adur-worthing.gov.uk>

Rebekah

The results have been presented in the correct way, including confirmation of UKAS accreditation, as is required within approved document E of the building regulation. The test appears to have been carried out as required and details the methodology in line with an appropriate standard. Not all rooms would be tested under the building regulation requirement and certain spaces such as stairs would not require testing. The information provided would be accepted as showing compliance with the building regulation standard.