



Rebekah Hincke
Adur & Worthing Councils
Portland House,
Richmond Road,
Worthing,
BN11 1LF

10 February 2026

Dear Rebekah,

RE: AWDM/1393/25 - 19 Farncombe Road Worthing West Sussex.

Thank you for your consultation on the above site. We have reviewed the application as the drainage consultant acting on behalf of the Council and wish to make the following comments.

The applicant is applying to vary condition 1 (Approved Drawings) to include railings, amended entrance gates, entrance ramp, amended patio steps, external land level adjustments, external guard rail to terrace and change of eastern casement window to sash. Amended details now include sustainable surface water drainage. Also variation of the following conditions to require compliance with newly submitted details: 4 - Construction Management Plan 5 - Biodiversity Gain Plan 6 - Landscape & Ecology Management Plan 7 - Surface Water Drainage Details 10 - Details of Windows and Doors 11 - Railings, Gates & Posts 12 - Cycle Parking ORIGINAL DESCRIPTION: AWDM/1522/24: Two-storey rear extension with first floor terrace to existing office (Use Class E); basement extension with front and rear lightwells; alterations to front boundary treatment and new rooflight to office building. The application is to Worthing Borough Council.

Following a review of the updated information, we note that updated calculations have been received demonstrating that a CV value of 1 has been utilised. However, we still have concerns regarding the following:

- Half drain time has been shown to be well above 24 hours. If a half drain time of 24 hours cannot be achieved, then we would expect to see consecutive storm calculations showing that the system can cope with a subsequent 1 in 10-year event without flooding occurring at the site.
- We recognise the use of catch pits and pretreatment measures; however, as a standard across all planning applications, we still require calculations to only use side infiltration.

We note that maintenance information has been received; however, this cannot be approved until the proposed method of drainage is approved in case of any changes to the drainage components. Therefore, we still require the following conditions to be attached to the approval of the application.

Condition 1: Construction shall not begin until a detailed surface water drainage scheme for the site has been submitted to and approved in writing by the Local Planning Authority. The surface water drainage scheme must prioritise the use of source control Sustainable Drainage Systems (SuDS) in consideration of the Non-Statutory Technical Standards for SuDS and demonstrate no increase in flood risk as a result of the Proposed Development with sufficient supporting evidence provided to support its viability including supporting calculations for the 100% AEP (1 in 1 year), 3.33% AEP (1 in 30 year), 3.33% AEP (1 in 30 year) plus climate change, the 1% AEP (1 in 100 year) and the 1% AEP (1 in 100) plus climate change critical storms. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring will be required to support the already provided infiltration testing and the design of any infiltration drainage. The scheme shall subsequently be implemented in accordance with the approved details before the development is completed.

Reason: To ensure the flood risk is adequately addressed and not increased in accordance with NPPF and Policies of Adur & Worthing Council.

Condition 2: The development hereby approved shall not be occupied until details of the maintenance and management of the sustainable drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the scheme to be submitted for approval shall include:

- I. a timetable for its implementation.
- II. details of SuDS feature and connecting drainage structures and maintenance requirement for each aspect including a drawing showing where they are located.
- III. a management and maintenance plan for the lifetime of the development which shall include details of design life and the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime. This will include the name and contact details of any appointed management company.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Policies of Adur and Worthing Council.

Yours sincerely,

Sustainable Water Management Officer