From: **FRS Water and Access** <FRSWaterandAccess@westsussex.gov.uk>
Date: Thu, 10 Apr 2025 at 07:18
Subject: Discharge of Fire Hydrant condition - AWDM/0302/25 Former Edf Car Park Southdownview Road Worthing West Sussex
To: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>

FAO: Louise Prew

Dear Louise,

Having viewed the details for planning application No. AWDM/0302/25 for the approval of details reserved by condition 32 (fire hydrant) of application AWDM/0056/22, I am satisfied that, providing the fire hydrant indicated on the plan is in place, ready for use, and WSFRS are informed it is ready for use, prior to any occupation of any of the units the fire hydrant condition will be met. Unfortunately, on too many occasions we are not informed it is ready for use which then puts lives and properties at a greater risk in the event of a fire.

Regards
Ian