From: Michael Lavender
Sent: 05 November 2012 10:29
To: 'andrew bower'; Peter Barnett
Subject: RE: Noise Report 10 Brighton Road Lancing AWDM/1031/12

Hi Peter,

Further to the attached report, I can confirm there would be no environmental health objections subject to the glazing on the A259 façade being 6/12/4 (or similar) glazing as recommended in the report. As the existing building is double aspect, ventilation can be achieved by opening windows on the Southern façade therefore no separate scheme for ventilation will be necessary in the conversion.

Kind Regards

Michael Lavender

From: andrew bower [mailto:aandcbower@sky.com]
Sent: 05 November 2012 09:55
To: Peter Barnett
Cc: Michael Lavender
Subject: Fwd: Noise Report 10 Brighton Road Lancing AWDM/1031/12

Peter
Attached is noise report for this proposal which I hope is satisfactory. I have copied it to Michael Lavender.
Hopefully the application can now be concluded?
Regards
Andy
PS Do you require a hard copy of the report?
---------- Forwarded message ----------
From: **George Orton** <georgeorton@aasussex.co.uk>
Date: Fri, Nov 2, 2012 at 4:56 PM
Subject: Noise Report
To: smdlyrichard@aol.com, aandcbower@sky.com

Richard

Here is the noise report as discussed and good luck with the application!

Many thanks

George Orton
--

Acoustic Associates Sussex Ltd

tel: 01273455074 email: georgeorton@aasussex.co.uk