Amanda Haslett

Subject: RE: AWDM/1400/23 - AWDM/1401/23 - 2 High Street Worthing

From: Richard Small <richard.small@adur-worthing.gov.uk>
Sent: 18 February 2025 16:24
To: Amanda Haslett <amanda.haslett@adur-worthing.gov.uk>
Subject: Re: AWDM/1400/23 - AWDM/1401/23 - 2 High Street Worthing

Hi Amanda,

It would appear that my concerns have largely been addressed with the latest set of drawings and updated Design, Access & Heritage Statement. The internal works to the floor to improve the sound insulation of the flying freehold appear to be acceptable and where the suspended ceilings are to be removed we are informed the old lath & plaster ceilings will be repaired on a like for like basis.

The use of some conditions would not seem unreasonable. This could include:
External pavers,
First floor stud partitioning fixing,

In my opinion the proposals are now supportable.

Kind regards
Richard

Richard Small
Design & Conservation Architect, Planning & Development
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk