From: Ashenden-Bax <ashendenbax@btinternet.com>
Sent: 17 March 2011 16:13
To: Peter Barnett
Subject: 24 Cheal Close

Follow Up Flag: Follow up
Flag Status: Flagged

Dear Mr Barnett

Following your telephone call this afternoon I visited the and can confirm that the width of the extension is 4500m which is the same as the approved plan and the length of the extension is 11600mm which is 262mm longer than the approved plan.

With regard to the comment that caused confusion in my letter of the 28th February 2011 at the fifth bullet point on the second page , what I was trying to explain was that the on the east elevation the approved extension was to be 100mm lower than the demolished building but as the building has been built 250mm higher than approved the next effect on the east elevation is that the extension as built is actually only 150mm higher than the original extension.

I hope that this information is helpful.

Yours sincerely

Maurice Ashenden-Bax
Chartered Architect