

From: Wendy Anderson <wendy.anderson@adur-worthing.gov.uk>
Sent: 29 January 2026 10:32:10 UTC+00:00
To: "Jo Morin" <jo.morin@adur-worthing.gov.uk>
Subject: AWDM/0063/26 worthing fish bar 74 heene rd

Hi Jo,

I have viewed the plans online and in respect of food hygiene, I have the following comments:

1. A wash hand basin for food handlers is not indicated on the plans and is required.
2. A wash hand basin to serve the toilet is not indicated on the plans and is required.
3. I assume that the walk in cooler is a walk in chiller?

Thanks, Wendy.

Wendy Anderson

Senior Environmental Health Officer, Environmental Health and Licensing
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
environmental.health@adur-worthing.gov.uk
www.adur-worthing.gov.uk
<https://www.adur-worthing.gov.uk/environmental-health/privacy-notice/>

