Millwood House Developments Ltd
Creating Connections in Construction
Structural Engineering Consultants

LADY BEE ENTERPRISE CENTRE SHOREHAM PORT SOUTHWICK
SUPPLEMENT TO CONTAMINATION VERIFICATION REPORT

This supplemental document to the Contamination Verification Report of 25th February 2019 is required to demonstrate that the Visqueen Gas Proof membrane was properly installed under each of the three buildings.

Please see attached photographs taken as the project progressed. Due to access reasons, Block 3, on the east side of the site was the first to be built followed by Block 2, in the centre of the site and Block 1 to the west side.

The Visqueen Gas Barrier membrane had lapped and taped joints together with VOC blok, the extra strong membrane under toes/edges of the raft foundation for extra protection at these vulnerable locations, in accordance with the manufacturer's specification.

The membrane was laid on smooth trowelled sand/cement blinding and overlaid with 30mm Kingspan Kooltherm K 103 Insulation which provided excellent protection to the membrane from the raft reinforcement.

This is to confirm that the gas proof membrane was properly laid under each of the three buildings.

Christopher Self C Eng FIStructE
Chartered Structural Engineer
March 2019.

The Studio 37 Manor Road East Preston West Sussex BN16 1QA
Managing Director : Christopher Self, C Eng F I Struct E
Company Secretary : Rafia Self, Dip Int. Design
Contamination/Environmental Consultant : Andrew Garnham BSc(Hons) MSc FGS
International Project Management Consultant ¡ Middle East : Andrew Turner BSc(Hons)

Tel. 07860 547459 E. chris@millwoodconsultants.co.uk
Registered office: 1 Harbour House, Harbour Way, Shoreham-by Sea, West Sussex, BN43 5HZ
Registered in England & Wales No 7284566 VAT Registration No: 995 5361 69



Block 3 from north west corner looking south. 25/09/2018



Block 3 from centre west looking south east. 25/09/2018



Block 2 from centre west looking north east. 03/10/2018



Block 2 from north east corner looking south. 05/10/2018



Block 1 from south looking north. 19/10/2018



Block 1 from north west looking south east. 10/10/2018