From: Michael Lavender <michael.lavender@adur-worthing.gov.uk>
Sent: 04 September 2024 11:37:16 UTC+01:00
To: "Jo Morin" <jo.morin@adur-worthing.gov.uk>
Subject: Re: AWDM/0964/24 Durrington High Sch AoC

Hi Jo,

there are no EH objections to Condition 10 being signed off.

Regards

Michael Lavender

On Wed, 4 Sept 2024 at 11:21, Jo Morin <jo.morin@adur-worthing.gov.uk> wrote:

> Hi Michael
>
> I wondered if you'd had a chance to look at the Noise report submitted to discharge Cond 10 of AWDM/1475/21 please? Cond 10 states:-
>
> *Any sound amplifying equipment for music or speech used in the Performing Arts building hereby permitted shall be controlled in volume and bass tone so as not to clearly impact above the existing background noise level at the curtilage of the nearest residential premises. The noise level from the new Performing Arts building shall not exceed 45dB LAeq5mins at the boundary of the site (the 'boundary noise level'). There shall not be any tonal noise associated with the development. Within one month of implementation of the development, a test shall be carried out and the result submitted to the Local Planning Authority to demonstrate compliance with the boundary noise level. Should this test show that the boundary noise level has not been complied with and notwithstanding the development hereby approved, a further scheme of attenuation works capable of achieving the boundary level shall be submitted to and agreed by the Local Planning Authority and completed within 3 months of the installation and thereafter retained.*
>
> See the note from Simon Barrett https://planning.adur-worthing.gov.uk/online-applications/
>
> Looks straightforward?
>
> Thanks
> --

Jo Morin
Principal Planning Officer, Planning & Development
01903 221350
Adur & Worthing Councils
Portland House, Richmond Road, Worthing, BN11 1LF
www.adur-worthing.gov.uk





--

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health



