

From: **Susie Quay**

Date: Thu, 16 Jul 2026 at 14:05

Subject: Re: Comments for Planning Application AWDM/0606/26

To: Jo Morin <jo.morin@adur-worthing.gov.uk>

Dear Jo,

Thank you for your prompt reply.

The elevations are misleading. The North elevation pointing towards my property shows a small velux on the bedroom. This does not comply to means of escape as it is too high above the floor (needs to be 1.1m from FFL to opening) and therefore it will either not copy to building regulations or will be installed larger than the drawings. This is also demonstrated on the section on drawing 21. They have a significant increase in foot print size and there is some planning guidance about a window being on the side within 2m of a neighbours boundary. I hope this information will also be taken into consideration.

Thanks,

Susie Quay