| | |
|---|---|
| **From:** | planning@adur-worthing.gov.uk |
| **Sent:** | 18 March 2020 14:32 |
| **To:** | planning@adur-worthing.gov.uk |
| **Subject:** | Consultee Comments for Planning Application AWDM/0083/20 |

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 2:32 PM on 18 Mar 2020 from Mrs Hannah Powell (hannah.powell@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

## Application Summary

**Reference:** AWDM/0083/20

**Address:** 4 The Street Shoreham-By-Sea West Sussex BN43 5NJ

**Proposal:** Single storey garden room for use as a drum room

**Case Officer:** Marie O'Keeffe

Click for further information

## Comments Details

**Comments:**

The proposed structure is in close proximity to a neighbouring dwelling. Insufficient information has been submitted with this application to demonstrate that this proposed use will not lead to noise disturbance.

The applicant refers to the use of sound proof plaster but no further information is included to demonstrate the level of attenuation this will provide. In addition, the window, door and roof are likely to be weak points acoustically so acoustic insulation and enhanced glazing needs to be considered.

Please could the applicant provide more details of the structure of the walls, glazing, door and roof and the level of attenuation each element will provide (including frequency data).

his is the application that I mentioned. Theapplication form says it will have sound proof plaster board on the walls bt no further info is provided. The window, door and the roof will obviously be weak points. I am thinking that they need to submit an assessment to demonstrate the level of noise within the room and the level of attenuation that the room will provide (as a whole including roof windows etc). Would a BS4142 assessment be appropriate?