From: Michael Lavender <michael.lavender@adur-worthing.gov.uk> on behalf of Michael Lavender
Sent: 11 December 2020 15:39
To: Peter Barnett
Subject: Re: AWDM/1912/20: Caxton House

Flag Status: Flagged

Thanks Peter,


they are ok.


Michael

On Fri, 11 Dec 2020 at 14:52, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:

> Hi Michael
>
> Vent details as requested.
>
> Thanks

Peter Barnett
Principal Planning Officer, Adur & Worthing Councils
Phone: 01903 221310
Email: peter.barnett@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Address: Development Management, Portland House, 44 Richmond Road, Worthing, BN11 1HS





---------- Forwarded message ---------
From: **Gary Cottle** <garycottle@gmail.com>
Date: Fri, 11 Dec 2020 at 14:47
Subject: Re: AWDM/1912/20: Caxton House
To: Peter Barnett <peter.barnett@adur-worthing.gov.uk>

Hi Peter

please find attached detail of the specification that meets the requirements.

I am about to forward a photo of the zinc shoulders and capping samples - would you like these dropped off or Richard to inspect on site?

many thanks

Gary


On Thu, 10 Dec 2020 at 13:13, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:


Gary

Please see the comments below. Would you please submit details of the acoustic vents as requested.

Thanks

Peter Barnett
Principal Planning Officer, Adur & Worthing Councils
Phone: 01903 221310
Email: peter.barnett@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Address: Development Management, Portland House, 44 Richmond Road, Worthing, BN11 1HS





---------- Forwarded message ---------
From: **Michael Lavender** <michael.lavender@adur-worthing.gov.uk>
Date: Wed, 9 Dec 2020 at 13:57
Subject: AWDM/1912/20: Caxton House
To: Peter Barnett <peter.barnett@adur-worthing.gov.uk>

Hello Peter,

The acoustic report sets out that standard double glazing is adequate for noise control, however, windows will need to remain closed to ensure noise standards are met. The applicant is proposing an exhaust ventilation system with additional extract fans in the bedrooms that are prone to overheating. These will depressurise the room drawing air in through the window vents. These window vents will need to be attenuated as advised in the acoustic report. If they can provide details of the proposed acoustic vents for the windows I am happy for this condition to be signed off.

Regards

Michael Lavender

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.

--

Michael Lavender
Senior Environmental Health Officer, Adur & Worthing Councils
Phone: 01273 263343
Email: michael.lavender@adur-worthing.gov.uk
Website: Environmental Health
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

