From: planning@adur-worthing.gov.uk
Sent: 24 October 2023 08:45
To: planning@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/0964/23

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 24/10/2023 8:45 AM from Mr Michael Lavender (michael.lavender@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0964/23
Address:	5 Eirene Avenue Worthing West Sussex BN12 4DL
Proposal:	Installation of an Air Source Heat Pump to the front elevation of the house
Case Officer:	Jason Albon

Click for further information

Comments Details

Comments:	HI, I note the noise report that was submitted has demonstrated a fail. If you can let me have a look at the manufacturers product data sheet for the ASHP, I will have a look at this. It is possible to confuse the SWL (Sound Power Level) with the SPL, (Sound Pressure Level), which would skew the results. I will get back to you once I have seen the data. Please e-mail it directly to me. Michael Lavender

Kind regards