From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 03 September 2024 15:16:14 UTC+01:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Consultee Comments for Planning Application AWDM/1045/24

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 03/09/2024 3:16 PM from Mr Oliver Rochford (oliver.rochford@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/1045/24
Address:	6 Warwick Street Worthing West Sussex BN11 3DL
Proposal:	External extraction system including flue
Case Officer:	Jackie Fox

Click for further information

Comments Details

Comments:	A document titled “KITCHEN EXTRACT, ODOUR CONTROL, NOISE ABATEMENT AND WASTE CONTROL DETAILS” was submitted in support of the above application. I am satisfied that the proposed plans are suitable for the intended cooking. Therefore the extraction system is to be installed in accordance with that outlined in the prior mentioned document and all duct work should be fitted on anti-vibration mounts.

Kind regards