FROST SITE, BRIGHTON ROAD, SHOREHAM

Discharge of Planning Condition 23 - Wheelchair Access – Apartments and All External Areas

23018-RVT-XX-GN-RP-A-7051 I 17.05.2024

RVT ARCHITECTS

Rev.	Date.	Revision Description.	Revised By.
R01	26.06.24	First Issue	RV

1. Table of Contents

1. Table Of Contents 3
2. Introduction 4
3. Details of planning condition 4
4. Information produced to support discharge of planning condition 4
5. Conclusion 5
Appendix A – Access Drawings 6

2. INTRODUCTION

This report has been prepared with the aim of addressing Condition 16 of the approved Planning Permission by Adur District Council for a development of the former Frosts Cars site at 69-75 Brighton Road, Shoreham-by-Sea under application number: AWDM/2039/22.

Planning Consent has been granted for the following development details;

Demolition of existing buildings, construction of 176no. One and two bedroom residential apartments and commercial development over 4 blocks between 5 and 9 levels, basement parking and raised deck, new highway access, flood defences, drainage Infrastructure, landscaping and ancillary development. (Including changes in heights and reduction from previously proposed 183no. apartments to 176no.).

3. DETAILS OF PLANNING CONDITION

Condition 23 - Wheelchair Access – Apartments and All External Areas

Accesses to the apartment block and all common external areas of the development using level thresholds and ramps shall provide for access by wheelchair users, unless otherwise approved in writing by the Local Planning Authority.

Reason:

To ensure accessibility for wheelchair users in accordance with policies 15, 28 & 32 of the Adur Local Plan 2017 and SH9 of the Shoreham Harbour Joint Area Action Plan 2019..

4. INFORMATION PRODUCED TO SUPPORT DISCHARGE OF PLANNING CONDITION

Condition 23

The development at the Frost site has been design to ensure high standards of accessibility for all users as described below:

Podium Level – All access pathways are either flat or have a gradient not steeper than 1:20. Wheelchair users have step free access to all areas in the podium and entrances to all buildings.

Basement level – Disabled car parking spaces have been provided at close proximity to building lift lobbies. All lift lobbies have level thresholds to provide accessibility for wheelchair users. Lift lobbies in the basement allow direct access to all levels in building 2, 3 & 4 as well as the podium (via building entrance lobbies).

Building 1 has been provided with a double sided lift to allow access from the entrance at Brighton Road to all levels including podium level. All corridors within the building have widths in excess of 1500mm. All apartment entrances have level thresholds from the communal corridor.

Buildings 2 & 3 have direct lift access from the basement as well as level access to the podium from building lobbies. All accessible corridors within the building have widths in excess of 1500mm. All apartment entrances have level thresholds from the communal corridor.

Building 4 has been provided with level access from the podium to the building lobby. A double sided lift connects the podium level to the basement and every level in the building. All corridors within the building have widths in excess of 1500mm. All apartment entrances have level thresholds from the communal corridor.

Communal Roofs – All roofs have a thicker buildup to meet the requirements of Part L U Values and requirement for fire ratings. Access ramps in line with the requirements of Part M are provided to permit access for all users to these communal spaces. .

Bin stores in buildings 1 & 4 have been provided with level access to bin stores. Buildings 2 & 3 have stepped access in addition to level access to bin stores. Generally, a space of minimum 1500mm has been provided across most areas in the bin stores, allowing wheelchair access to all types of bins.

Emergency egress – Although not a Building Regs requirement, all buildings are provided with evacuation lifts serving all floors to provide safe egress for wheelchair users in an emergency.

5. CONCLUSION

The enclosed drawings clarifies the requested detail in regard to Condition 23 of the Planning Consent for the 69-75 Brighton Road development to provide access to wheelchair users to all apartment blocks and all common external areas of the development using level thresholds and ramps.

Appendix A – Access drawings

- SHR01-RVT-000-00-DR-A-2001_SITE PLAN -PART M ACCESS STRATEGY PLAN
- SHR01-RVT-000-B1-DR-A-2002_BASEMENT LEVEL PART M ACCESS STRATEGY PLAN
- SHR01-RVT-001-ZZ-DR-A-2010_BUILDING 01 - LEVEL 00 & LEVEL 01 PART M ACCESS STRATEGY PLANS
- SHR01-RVT-002-ZZ-DR-A-2020_BUILDING 02 - LEVEL 00 & TYPICAL LEVEL 01 TO LEVEL 04 PART M ACCESS STRATEGY PLANS
- SHR01-RVT-002-ZZ-DR-A-2021_BUILDING 02 - LEVEL 05 & LEVEL 06 PART M ACCESS STRATEGY PLANS
- SHR01-RVT-003-ZZ-DR-A-2030_BUILDING 03 - LEVEL 00 & TYPICAL LEVEL 01 TO LEVEL 04 PART M ACCESS STRATEGY PLANS
- SHR01-RVT-003-ZZ-DR-A-2031_BUILDING 03 - LEVEL 05 & LEVEL 06 PART M ACCESS STRATEGY PLANS
- SHR01-RVT-004-ZZ-DR-A-2040_BUILDING 04 - LEVEL 00 & TYPICAL LEVEL 01 TO LEVEL 04 PART M ACCESS STRATEGY PLAN
- SHR01-RVT-004-07-DR-A-2042_BUILDING 04 - LEVEL 07 PART M ACCESS STRATEGY PLAN



SITE PLAN - PART M ACCESS STRATEGY PLAN

1 : 200

0m 4m 8m 12m 16m 20m

SCALE 1:200 @ A1

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL, OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

Legend:

Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.

Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.

Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.

Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.

The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step free, level or where unavoidable, gently sloping.

Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.

Refuge Area

No.	Description	Date
P02	ISSUED FOR CONDITIONS	26.07.24
P01	ISSUED FOR INFORMATION	11.06.24

Key Plan

North

CLIENT:

New Ways
Modern, sustainable building
Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

VIVID

SITE PLAN -PART M ACCESS STRATEGY PLAN
PODIUM LEVEL

DRN.	DATE	CKD.	DATE	APP.	DATE
TN	03.05.24	GZ	03.05.24	RV	07.05.24

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:200@A1

PROJECT No	ORIG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER
SHR01	RVT	000	00	DR	A	2001

P02

FILE PATH: Autodesk Docs://Shoreham By Sea/23018-RVT-05-ZZ-M3-A-0005 - PODIUM.rvt



BASEMENT - PART M ACCESS STRATEGY PLAN

1 : 150

0m 3m 6m 9m 12m 15m

SCALE 1:150 @ A1

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

PLT PATH: Autodesk Docs://Shoreham By Sea/23018-RVT-05-ZZ-M3-A-0005 - PODIUM.rvt

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

Legend:

Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.

Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.

Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.

Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.

The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step-free, level or where unavoidable, gently sloping.

Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.

Refuge Area

No.	Description	Date
P03	ISSUED FOR CONDITIONS	26.07.24
P02	ISSUED FOR INFORMATION	11.06.24
P01	ISSUED FOR COORDINATION	20.12.23

Key Plan

North

CLIENT:

New Ways
Modern, sustainable building
Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

VIVID

BASEMENT LEVEL PART M ACCESS STRATEGY PLAN

DRN.	DATE	CKD.	DATE	APP.	DATE
TN	02.12.2023	GZ	18.12.2023	RV	19.12.2023

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:150@A1

PROJECT No	ORIG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER
SHR01	RVT	000	B1	DR	A	2002

P03



LEVEL 00 - PART M ACCESS STRATEGY PLAN

1 : 100



LEVEL 01 - PART M ACCESS STRATEGY PLAN

1 : 100

0m 2m 4m 6m 8m 10m

SCALE 1:100 @ A1

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

TLE ReCit: Autodesk Docs://Shoreham By Sea/23018-RVT-B1-ZZ-M3-A-0001 - BUILDING 01.rvt

Legend:

Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.

Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.

Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.

Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.

The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

Private entrances
The private entrance doors have a minimum clear opening width of 850mm with an accessible level threshold.

External doors
All external balcony doors have a minimum clear opening width of 850mm with an accessible threshold.

Internal doors
To facilitate access into habitable rooms and to a WC, door widths have a minimum clear opening of 800mm.

Hall widths
To facilitate access into private dwellings the hall width complies with the minimum clear passageway width of 900mm with localised obstructions not permitted within 1500mm.

Kitchen areas
A minimum 1200mm clear space provided in front of and between all kitchen units and appliances.

Bedrooms
The principal bedroom has a clear access zone, a minimum 750mm wide to both sides and the foot of the bed. Every other double bedroom can provide a clear access zone, a minimum 750mm wide to both side and the foot of the bed. 600mm bedside furniture permitted in zone. Can demonstrate that the provisions above can achieve in our flat layout plans.

WC access zone
Clear space to access the WC, minimum 900mm wide and 1100mm deep.

Wash hand basin access zone
Clear space to access wash hand basin, minimum 700mm wide and 1100mm deep with maximum encroachment 300mm. Basins do not project into access zones in such a way as to impede access.

Shower space access zone
Clear space to access the shower space, minimum 1100mm wide and 700mm deep.

Services and controls
To assist people who have reduced reach, services and controls serving habitable rooms throughout the dwelling have their centre line 450-1200mm above floor level, as depicted. Door viewers supplied only as required at 1200mm.

Shower installation
Clear Ability to install showers at level for the First Floor only.
Note, All first floor flats have the ability to reorganise/modify to be compliant towards future proofing by strategy location of structural walls, however these are not constructed in the first instance itself.

Roof terrace
To enable use to roof terrace, access provided by a door that has a minimum clear opening width of 850mm, a minimum 300mm nib to the leading edge and a minimum 200mm nib to the following edge.

Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step free, level or where unavoidable, gently sloping.

Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.

Refuge Area

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

No.	Description	Date
P02	ISSUED FOR CONDITIONS	26.07.24
P01	ISSUED FOR COORDINATION	20.12.23

Key Plan



CLIENT:

New Ways
Modern, sustainable building
Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

BUILDING 01 - LEVEL 00 & LEVEL 01 PART M ACCESS STRATEGY PLANS

DRN.	DATE.	CKD.	DATE.	APP.	DATE.
TN	10.10.23	GZ	12.10.23	RV	12.10.23

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:100@A1

PROJECT No	ORIG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER
SHR01	RVT	001	ZZ	DR	A	2010

P02

PLOTTED AT 1:1





LEVEL 00 - PART M ACCESS STRATEGY PLAN

1 : 100



Legend:

Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.

Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.

Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.

Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.

The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.



Private entrances
The private entrance doors have a minimum clear opening width of 850mm with an accessible threshold.

External doors
All external balcony doors have a minimum clear opening width of 850mm with an accessible threshold.

Internal doors
To facilitate access into habitable rooms and to a WC, door widths have a minimum clear opening of 800mm.

Hall widths
To facilitate access into private dwellings the hall width complies with the minimum clear passageway width of 900mm with localised obstructions not permitted within 1500mm.

Kitchen areas
A minimum 1200mm clear space provided in front of and between all kitchen units and appliances.

Bedrooms
The principal bedroom has a clear access zone, a minimum 750mm wide to both sides and the foot of the bed. Every other double bedroom can provide a clear access zone, a minimum 750mm wide to both side and the foot of the bed. 600mm bedside furniture permitted in zone. Can demonstrate that the provisions above can achieve in our flat layout plans.



WC access zone
Clear space to access the WC, minimum 900mm wide and 1100mm deep.

Wash hand basin access zone
Clear space to access wash hand basin, minimum 700mm wide and 1100mm deep with maximum encroachment 300mm. Basins do not project into access zones in such a way as to impede access.

Shower space access zone
Clear space to access the shower space, minimum 1100mm wide and 700mm deep.

Services and controls
To assist people who have reduced reach, services and controls serving habitable rooms throughout the dwelling have their centre line 450-1200mm above floor level, as depicted. Door viewers supplied only as required at 1200mm.

Refuge Area

Shower installation
Clear Ability to install showers at level for the First Floor only.
Note, All first floor flats have the ability to reorganise/modify to be compliant towards future proofing by strategy location of structural walls, however these are not constructed in the first instance itself.

Roof terrace
To enable use to roof terrace, access provided by a door that has a minimum clear opening width of 850mm, a minimum 300mm nib to the leading edge and a minimum 200mm nib to the following edge.



Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step free, level or where unavoidable, gently sloping.

Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.

SCALE 1:100 @ A1

LEVEL 01 TO 04 - PART M ACCESS STRATEGY PLAN

1 : 100

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL, OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

FILE PATH: Autodesk Docs://Shoreham By Sea/23018-RVT-BZ-ZZ-M3-A-0002 - BUILDING 02.rvt

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

No.	Description	Date
P02	ISSUED FOR CONDITIONS	26.07.24
P01	ISSUED FOR COORDINATION	20.12.23

Key Plan



CLIENT:

New Ways
Modern, sustainable building
Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

BUILDING 02 - LEVEL 00 & TYPICAL LEVEL 01 TO LEVEL 04 PART M ACCESS STRATEGY PLANS

DRN.	DATE.	CKD.	DATE.	APP.	DATE.
TN	10.10.23	GZ	12.10.23	RV	12.10.23

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:100@A1

PROJECT No	ORG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER
SHR01	RVT	002	ZZ	DR	A	2020

P02

PRODUCED BY RVT



LEVEL 05 - PART M ACCESS STRATEGY PLAN

1 : 100



LEVEL 06 - PART M ACCESS STRATEGY PLAN

1 : 100

Legend:



Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.

Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.

Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.

Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.

The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.



Private entrances
The private entrance doors have a minimum clear opening width of 850mm with an accessible threshold.

External doors
All external balcony doors have a minimum clear opening width of 850mm with an accessible threshold.

Internal doors
To facilitate access into habitable rooms and to a WC, door widths have a minimum clear opening of 800mm.

Hall widths
To facilitate access into private dwellings the hall width complies with the minimum clear passageway width of 900mm with localised obstructions not permitted within 1500mm.

Kitchen areas
A minimum 1200mm clear space provided in front of and between all kitchen units and appliances.

Bedrooms
The principal bedroom has a clear access zone, a minimum 750mm wide to both sides and the foot of the bed. Every other double bedroom can provide a clear access zone, a minimum 750mm wide to both side and the foot of the bed. 600mm bedside furniture permitted in zone. Can demonstrate that the provisions above can achieve in our flat layout plans.



WC access zone
Clear space to access the WC, minimum 900mm wide and 1100mm deep.

Wash hand basin access zone
Clear space to access wash hand basin, minimum 700mm wide and 1100mm deep with maximum encroachment 300mm. Basins do not project into access zones in such a way as to impede access.

Shower space access zone
Clear space to access the shower space, minimum 1100mm wide and 700mm deep.

Services and controls
To assist people who have reduced reach, services and controls serving habitable rooms throughout the dwelling have their centre line 450-1200mm above floor level, as depicted. Door viewers supplied only as required at 1200mm.

Refuge Area

Shower installation
Clear Ability to install showers at level for the First Floor only.
Note, All first floor flats have the ability to reorganise/modify to be compliant towards future proofing by strategy location of structural walls, however these are not consructed in the first instance itself.

Roof terrace
To enable use to roof terrace, access provided by a door that has a minimum clear opening width of 850mm, a minimum 300mm nib to the leading edge and a minimum 200mm nib to the following edge.



Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step free, level or where unavoidable, gently sloping.

Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.



SCALE 1:100 @ A1

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL, OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

DLE PATH: Autodesk Docs://Shoreham By Sea/23018-RVT-B2-ZZ-M3-A-0002 - BUILDING 02.rvt

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

No.	Description	Date
P02	ISSUED FOR CONDITIONS	26.07.24
P01	ISSUED FOR COORDINATION	20.12.23

Key Plan



CLIENT:

New Ways
Modern, sustainable building
Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

BUILDING 02 - LEVEL 05 & LEVEL 06 PART M ACCESS STRATEGY PLANS

DRN.	DATE.	CKD.	DATE.	APP.	DATE.
TN	10.10.23	GZ	12.10.23	RV	12.10.23

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:100@A1

PROJECT No	ORIG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER	
SHR01	RVT	002	ZZ	DR	A	2021	P02





LEVEL 00 - PART M ACCESS STRATEGY PLAN

1 : 100



Legend:

Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.

Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.

Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.

Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.

The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.



Private entrances
The private entrance doors have a minimum clear opening width of 850mm with an accessible threshold.

External doors
All external balcony doors have a minimum clear opening width of 850mm with an accessible threshold.

Internal doors
To facilitate access into habitable rooms and to a WC, door widths have a minimum clear opening of 800mm.

Hall widths
To facilitate access into private dwellings the hall width complies with the minimum clear passageway width of 900mm with localised obstructions not permitted within 1500mm.

Kitchen areas
A minimum 1200mm clear space provided in front of and between all kitchen units and appliances.

Bedrooms
The principal bedroom has a clear access zone, a minimum 750mm wide to both sides and the foot of the bed. Every other double bedroom can provide a clear access zone, a minimum 750mm wide to both side and the foot of the bed. 600mm bedside furniture permitted in zone. Can demonstrate that the provisions above can achieve in our flat layout plans.

0m 2m 4m 6m 8m 10m

SCALE 1:100 @ A1

LEVEL 01 TO LEVEL 04 - PART M ACCESS STRATEGY PLAN

1 : 100



WC access zone
Clear space to access the WC, minimum 900mm wide and 1100mm deep.

Wash hand basin access zone
Clear space to access wash hand basin, minimum 700mm wide and 1100mm deep with maximum encroachment 300mm. Basins do not project into access zones in such a way as to impede access.

Shower space access zone
Clear space to access the shower space, minimum 1100mm wide and 700mm deep.

Wheelchair Shower space access zone
Clear space to access the shower space, minimum 1500mm diameter circle

Services and controls
To assist people who have reduced reach, services and controls serving habitable rooms throughout the dwelling have their centre line 450-1200mm above floor level, as depicted. Door viewers supplied only as required at 1200mm.

Refuge Area

Shower installation
Clear Ability to install showers at level for the First Floor only.
Note, All first floor flats have the ability to reorganise/modify to be compliant towards future proofing by strategy location of structural walls, however these are not constructed in the first instance itself.

Roof terrace
To enable use to roof terrace, access provided by a door that has a minimum clear opening width of 850mm, a minimum 300mm nib to the leading edge and a minimum 200mm nib to the following edge.



Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step free, level or where unavoidable, gently sloping.

Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL, OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

XLF Path: Autodesk Docs://Shoreham By Sea/23018-RVT-83-ZZ-M3-A-0003 - BUILDING 03.rvt

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

No.	Description	Date
P02	ISSUED FOR CONDITIONS	26.07.24
P01	ISSUED FOR COORDINATION	20.12.23

Key Plan



CLIENT:

New Ways
Modern, sustainable building
Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

BUILDING 03 - LEVEL 00 & TYPICAL LEVEL 01 TO LEVEL 04 PART M ACCESS STRATEGY PLANS

DRN.	DATE.	CKD.	DATE.	APP.	DATE.
TN	10.10.23	GZ	12.10.23	RV	12.10.23

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:100@A1

PROJECT No	ORIG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER	
SHR01	RVT	003	ZZ	DR	A	2030	P02

Printed at A3





LEVEL 05 - PART M ACCESS STRATEGY PLAN

1 : 100

LEVEL 06 - PART M ACCESS STRATEGY PLAN

1 : 100

Legend:



Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.

Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.

Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.

Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.

The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.

The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.



Private entrances
The private entrance doors have a minimum clear opening width of 850mm with an accessible threshold.

External doors
All external balcony doors have a minimum clear opening width of 850mm with an accessible threshold.

Internal doors
To facilitate access into habitable rooms and to a WC, door widths have a minimum clear opening of 800mm.

Hall widths
To facilitate access into private dwellings the hall width complies with the minimum clear passageway width of 900mm with localised obstructions not permitted within 1500mm.

Kitchen areas
A minimum 1200mm clear space provided in front of and between all kitchen units and appliances.

Bedrooms
The principal bedroom has a clear access zone, a minimum 750mm wide to both sides and the foot of the bed. Every other double bedroom can provide a clear access zone, a minimum 750mm wide to both side and the foot of the bed. 600mm bedside furniture permitted in zone. Can demonstrate that the provisions above can achieve in our flat layout plans.



WC access zone
Clear space to access the WC, minimum 900mm wide and 1100mm deep.

Wash hand basin access zone
Clear space to access wash hand basin, minimum 700mm wide and 1100mm deep with maximum encroachment 300mm. Basins do not project into access zones in such a way as to impede access.

Shower space access zone
Clear space to access the shower space, minimum 1100mm wide and 700mm deep.

Wheelchair Shower space access zone
Clear space to access the shower space, minimum 1500mm diameter circle

Services and controls
To assist people who have reduced reach, services and controls serving habitable rooms throughout the dwelling have their centre line 450-1200mm above floor level, as depicted. Door viewers supplied only as required at 1200mm.

Refuge Area

Shower installation
Clear Ability to install showers at level for the First Floor only.
Note, All first floor flats have the ability to reorganise/modify to be compliant towards future proofing by strategy location of structural walls, however these are not constructed in the first instance itself.

Roof terrace
To enable use to roof terrace, access provided by a door that has a minimum clear opening width of 850mm, a minimum 300mm nib to the leading edge and a minimum 200mm nib to the following edge.



Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step free, level or where unavoidable, gently sloping.



Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.



SCALE 1:100 @ A1

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

XLE Path: Autodesk Docs://Shoreham By Sea/23018-RVT-83-ZZ-M3-A-0003 - BUILDING 03.rvt

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

No.	Description	Date
P02	ISSUED FOR CONDITIONS	26.07.24
P01	ISSUED FOR COORDINATION	20.12.23

Key Plan



CLIENT:

New Ways
Modern, sustainable building
Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

BUILDING 03 - LEVEL 05 & LEVEL 06 PART M ACCESS STRATEGY PLANS

DRN.	DATE	CKD.	DATE	APP.	DATE
TN	10.10.23	GZ	12.10.23	RV	12.10.23

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:100@A1

PROJECT No	ORIG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER
SHR01	RVT	003	ZZ	DR	A	2031

P02

Plotted on A1



LEVEL 00 - PART M ACCESS STRATEGY PLAN

1 : 100



LEVEL 00 to 04 - PART M ACCESS STRATEGY PLAN

1 : 100

0m 2m 4m 6m 8m 10m

SCALE 1:100 @ A1

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

TLE ReDir: Autodesk Docs://Shoreham By Sea/23018-RVT-B4-ZZ-M3-A-0004 - BUILDING 04.rvt

Legend:



Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.



Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.



Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.



Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.



The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.



The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.



Private entrances
The private entrance doors have a minimum clear opening width of 850mm with an accessible threshold.



External doors
All external balcony doors have a minimum clear opening width of 850mm with an accessible threshold.



Internal doors
To facilitate access into habitable rooms and to a WC, door widths have a minimum clear opening of 800mm.



Hall widths
To facilitate access into private dwellings the hall width complies with the minimum clear passageway width of 900mm with localised obstructions not permitted within 1500mm.



Kitchen areas
A minimum 1200mm clear space provided in front of and between all kitchen units and appliances.



Bedrooms
The principal bedroom has a clear access zone, a minimum 750mm wide to both sides and the foot of the bed. Every other double bedroom can provide a clear access zone, a minimum 750mm wide to both side and the foot of the bed. 600mm bedside furniture permitted in zone. Can demonstrate that the provisions above can achieve in our flat layout plans.



WC access zone
Clear space to access the WC, minimum 900mm wide and 1100mm deep.



Wash hand basin access zone
Clear space to access wash hand basin, minimum 700mm wide and 1100mm deep with maximum encroachment 300mm. Basins do not project into access zones in such a way as to impede access.



Shower space access zone
Clear space to access the shower space, minimum 1100mm wide and 700mm deep.



Services and controls
To assist people who have reduced reach, services and controls serving habitable rooms throughout the dwelling have their centre line 450-1200mm above floor level, as depicted. Door viewers supplied only as required at 1200mm.



Shower installation
Clear Ability to install showers at level for the First Floor only.
Note, All first floor flats have the ability to reorganise/modify to be compliant towards future proofing by strategy location of structural walls, however these are not constructed in the first instance itself.



Roof terrace
To enable use to roof terrace, access provided by a door that has a minimum clear opening width of 850mm, a minimum 300mm nib to the leading edge and a minimum 200mm nib to the following edge.



Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step free, level or where unavoidable, gently sloping.



Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.



Refuge Area

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

No.	Description	Date
P02	ISSUED FOR CONDITIONS	26.07.24
P01	ISSUED FOR COORDINATION	20.12.23

Key Plan



CLIENT:

New Ways
Modern, sustainable building
Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA
Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

BUILDING 04 - LEVEL 00 & TYPICAL LEVEL 01 TO LEVEL 04 PART M ACCESS STRATEGY PLAN

DRN.	DATE.	CKD.	DATE.	APP.	DATE.
TN	10.10.23	GZ	12.10.23	RV	12.10.23

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:100@A1

PROJECT No	ORIG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER
SHR01	RVT	004	ZZ	DR	A	2040

P02

PLOTTED BY RVT



LEVEL 07 - PART M ACCESS STRATEGY PLAN

1 : 100



SCALE 1:100 @ A1

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF RVT ARCHITECTS LTD. NO REPRODUCTION IN FULL OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT FROM RVT ARCHITECTS LTD.

TLE ReCit: Autodesk Docs://Shoreham By Sea/23018-RVT-B4-ZZ-M3-A-0004 - BUILDING 04.rvt

Legend:



Principal entrance and Communal doors
The principal entrance and communal doors have a minimum clear opening width of 850mm with an accessible threshold. Where there are double doors, the main (or leading) leaf provides the required minimum clear opening width stated above.



Communal lifts
Communal lifts, there is a clear landing minimum 1500mm long and 1500mm wide, directly in front of the lift door at every floor level.



Communal lifts, the car is a minimum 1100mm wide and 1400mm deep inside. Doors have a minimum clear opening width of 800mm.



Communal stairs
The principal communal stairs comply with requirements of Part B for a firefighting stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread. Not ambulant disabled, nor refuges but comply towards fire regulations. Handrails intruding by a maximum of 100mm each side is ignored.



The principal communal stairs comply with requirements of Part K for a general access stair for a minimum clear stair width of 1000mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.



The communal stairs comply with requirements of Part K for a utility stair for a minimum clear stair width of 1100mm with handrail on both sides having key dimension of 300mm minimum from the first or last tread.



Private entrances
The private entrance doors have a minimum clear opening width of 850mm with an accessible threshold.

External doors
All external balcony doors have a minimum clear opening width of 850mm with an accessible threshold.



Internal doors
To facilitate access into habitable rooms and to a WC, door widths have a minimum clear opening of 800mm.



Hall widths
To facilitate access into private dwellings the hall width complies with the minimum clear passageway width of 900mm with localised obstructions not permitted within 1500mm.



Kitchen areas
A minimum 1200mm clear space provided in front of and between all kitchen units and appliances.



Bedrooms
The principal bedroom has a clear access zone, a minimum 750mm wide to both sides and the foot of the bed. Every other double bedroom can provide a clear access zone, a minimum 750mm wide to both side and the foot of the bed. 600mm bedside furniture permitted in zone. Can demonstrate that the provisions above can achieve in our flat layout plans.



WC access zone
Clear space to access the WC, minimum 900mm wide and 1100mm deep.



Wash hand basin access zone
Clear space to access wash hand basin, minimum 700mm wide and 1100mm deep with maximum encroachment 300mm. Basins do not project into access zones in such a way as to impede access.



Shower space access zone
Clear space to access the shower space, minimum 1100mm wide and 700mm deep.



Services and controls
To assist people who have reduced reach, services and controls serving habitable rooms throughout the dwelling have their centre line 450-1200mm above floor level, as depicted. Door viewers supplied only as required at 1200mm.



Shower installation
Clear Ability to install showers at level for the First Floor only.
Note, All first floor flats have the ability to reorganise/modify to be compliant towards future proofing by strategy location of structural walls, however these are not constructed in the first instance itself.



Roof terrace
To enable use to roof terrace, access provided by a door that has a minimum clear opening width of 850mm, a minimum 300mm nib to the leading edge and a minimum 200mm nib to the following edge.



Parking space
Communal parking space provided, at least one standard parking bay provided close to the communal entrance of each core having a minimum clear access zone of 900mm to one side, it is step free, level or where unavoidable, gently sloping.



Principal communal entrances
Step free approach from parking space to principal entrance with shallowest gradient beyond 1:21 and with firm, even and slip resistant ground surface suitable for wheelchair use. Zone indicated showcases more than the required 1500 x 1500mm level landing directly outside the entrance door, which is clear of any outward opening door swings.



Refuge Area

Do not scale from drawings. Verify all dimensions on site prior to construction. This drawing is to be read in conjunction with all relevant documents and drawings. Report all discrepancies to RVT Architects immediately.
No unauthorised use, disclosure, storage or copying.

Notes

No.	Description	Date
P02	ISSUED FOR CONDITIONS	26.07.24
P01	ISSUED FOR COORDINATION	20.12.23

Key Plan



CLIENT:

New Ways
Modern, sustainable building

Unit 8 Carnival Park, Carnival Close, Basildon SS14 3WN

RVT ARCHITECTS
4a Old Lodge Lane,
Purley, CR8 4DE.
T +44 203 740 2130
E: info@rvtarchitects.com
W: rvtarchitects.com
RIBA
Chartered Practice

PROJECT NAME:

SHOREHAM BY SEA
69 - 75 BRIGHTON ROAD
BN43 6RE

BUILDING 04 - LEVEL 07 PART M ACCESS STRATEGY PLAN

DRN.	DATE.	CKD.	DATE.	APP.	DATE.
TN	10.10.23	GZ	12.10.23	RV	12.10.23

STATUS: ISSUED FOR CONDITIONS
SCALE: 1:100@A1

PROJECT No	ORIG.	VOLUME	LEVEL	DOC. TYPE	DISC.	SEQ. NUMBER	
SHR01	RVT	004	07	DR	A	2042	P02

ALL DIMENSIONS AT A1