From: Michael Lavender <michael.lavender@adur-worthing.gov.uk>
Sent: 14 August 2024 11:29:39 UTC+01:00
To: "Jason Albon" <jason.albon@adur-worthing.gov.uk>
Cc: "Nadeem Shad" <nadeem.shad@adur-worthing.gov.uk>
Subject: Re: Planning Application AWDM/0794/24 172 Alinora Crescent

Hi Jason,

Nadeem had this application.

Is there any reason the applicant has not applied for Permitted Development using the MCS scheme. There is no MCS noise assessment or any details of the ASHP that is to be installed. That said, looking at the proposed positioning of the ASHP and distance to the nearest receptors it is unlikely that noise will be a problem so there will be no EH objections.

Regards

Michael Lavender

On Mon, 5 Aug 2024 at 11:11, Jason Albon <jason.albon@adur-worthing.gov.uk> wrote:

> Hi Michael,
>
> Hope you are well. I note we haven't received comments from EPH regarding the ASHP application at 172 Alinora Crescent. You have provided comments for a similar application at 20 Rugby Road (AWDM/0794/24) for the same ASHP (no objection). Could you please confirm EPH stance?
>
> Kind regards,

Jason Albon
Planning Officer, Planning & Development
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk





--

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health



