

Classification Report

Number	24-004241-PR01 (NW-A01-05-en-02)
Owner	Fieger Lamellenfenster GmbH Auf der Aue 10 69488 Birkenau Germany
Product	Burglar resistant lamella window
Designation	System: FLW32
Details	Manufacturer Fieger Lamellenfenster GmbH, Birkenau; Material Aluminium with thermal break; Attack side Outside of building structure; Type of opening Horizontal pivot casement; Installation According to the testing documentation of the attached manufacturer's installation instructions; Overall dimensions (W x H) 1,580 mm x 1,800 mm; Number of casements 5; LSG: Manufacturer SANCO; Type SANCO Plus 2-fach P4A; Note Class: P4A acc. to EN 356; Motor E-motor LDF 1400/1800 D+H
Special features	-/-

Result **)

Burglary resistance according to EN 1627:2021-06



Class: RC 2 / RC 2N

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

Basis *)

EN 1627:2021-06

*) and corresponding national versions
(e.g. DIN EN)

Test report: 24-004241-PR01 PB-A01-05-de-03

Replaces ift-Nachweis:

24-004241-PR01 NW-A01-05-en-01 dated 13.06.2025.

Representation



Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
11.07.2025

Simon Stüer
Deputy Head of Testing Department
Security/Safety Testing

Thomas Zimmer, M.Sc.
Operating Testing Officer
Security/Safety Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 232-6B022