Marie O'Keeffe
Adur & Worthing Councils
Portland House,
Richmond Road,
Worthing,
BN11 1LF

11 April 2025

Dear Marie,

RE: **AWDM/0088/25 - Land South Of 14 Halewick Close Sompting West Sussex**

Thank you for your consultation on the above site. We have reviewed the application as the drainage consultant acting on behalf of the Council and wish to make the following comments.

The applicant is applying for the change of use from garden land to parking area with single storey detached garage with loft space/storage above. The application is to Adur District Council.

Following a review of the submitted information, we have no objection on surface water grounds. Due to the site, size, location, and type of development **we would recommend the approval of the application** with the following conditions attached:

Condition 1: Construction shall not begin until a detailed surface water drainage scheme for the site has been submitted to and approved in writing by the Local Planning Authority. The surface water drainage scheme must prioritise the use of source control Sustainable Drainage Systems (SuDS) in consideration of the Non-Statutory Technical Standards for SuDS and demonstrate no increase in flood risk as a result of the Proposed Development with sufficient supporting evidence provided to support its viability including supporting calculations for the 100% AEP (1 in 1 year), 3.33% AEP (1 in 30 year), 3.33% AEP (1 in 30 year) plus climate change, the 1% AEP (1 in 100 year) and the 1% AEP (1 in 100) plus climate change critical storms. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring and winter infiltration testing to BRE DG365, or similar approved, will be required to support the design of any infiltration drainage. The scheme shall subsequently be implemented in accordance with the approved details before the development is completed.

Matrix House
Basing View
Basingstoke, Hampshire
RG21 4FF
Tel: +44 1256 318 800
wsp.com

WSP UK Limited | Registered address: WSP House, 70 Chancery Lane, London WC2A 1AF
Registered in England and Wales No. 01383511

Reason: To ensure the flood risk is adequately addressed and not increased in accordance with NPPF and Policies of Adur & Worthing Council.

Condition 2: The development hereby approved shall not be occupied until details of the maintenance and management of the sustainable drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the scheme to be submitted for approval shall include:

I. a timetable for its implementation.
II. details of SuDS feature and connecting drainage structures and maintenance requirement for each aspect including a drawing showing where they are located.
III. a management and maintenance plan for the lifetime of the development which shall include details of design life and the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime. This will include the name and contact details of any appointed management company.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Policies of Adur and Worthing Council.

Yours sincerely,

Sustainable Water Management Officer