From: Michael Lavender <michael.lavender@adur-worthing.gov.uk> on behalf of Michael Lavender
Sent: 27 October 2023 14:38
To: Peter Barnett
Subject: AWDM/1319/23: 85 - 89 Brighton Road, Lancing

Flag Status: Flagged

Hi Peter,

The Titon SF XTRA meets the acoustic specification for the window vents outlined in the original acoustic report..

Based on the same acoustic report the glazing required for rooms facing Brighton Road is below

-

Insulating glass units										
6 mm / 16 mm argon / 6.8 mm Pilkington **Optiphon**™	21	28	37	48	48	54	40 (-2; -6)	40	38	34

If this is installed I have no objections to the condition being signed off.

Regards

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health



