From: **darren moore**
Date: Thu, 11 Nov 2021 at 15:32
Subject: Re: AWDM/1717/21 : LDC Hip to gable, side dormer etc : 16 St James Ave., Lancing
To: Eve Hearsey <eve.hearsey@adur-worthing.gov.uk>

Hi Eve

I got your voicemail. Sorry for the confusion. Yes, I can confirm the window on the dormer side will have obscure glass and will be fixed below 1.7m from ffl. I can also confirm that the roof windows on the opposite side will protrude no more than 150mm from the pitched tiled roof line.

Regards

Darren Moore

Facebook