From: **Michael Lavender** <michael.lavender@adur-worthing.gov.uk>
Date: Wed, 20 Nov 2024 at 16:00
Subject: AWDM/1108/24: Approval of Details Reserved by Condition 6 of Application AWDM/1847/22.
To: Louise Prew <louise.prew@adur-worthing.gov.uk>

Hi Louise,

I am unable to assess whether the noise from the ASHP is acceptable based on the information provided.

06. Prior to the installation of the Air Source Heat Pump details of its final specification including size, appearance and noise output, including any necessary mitigation measures, shall be submitted in writing to the local planning authority for approval. Only such details as approved shall be installed and thereafter retained.

Reason: In the interest of neighbour amenity and the setting of the listed building having regard to the National Planning Policy Framework and polices DM22, DM23 and DM24 of the Worthing local plan.

The applicant has not put forward any noise mitigation measures with the information. Unless the applicant has undertaken the noise assessment then there is no way of demonstrating that noise mitigation measures.are not necessary and in my opinion he has not fulfilled the requirements of the condition and I would object to the condition being signed off.

Regards

Michael Lavender
Senior Environmental Health Officer, Public Health & Regulation
01273 263343
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Environmental Health