ADUR DISTRICT COUNCIL

Mr Peter Southgate
Atelier Consultants
44A High Street
STEYNING
BN44 3YE

PLANNING PERMISSION

TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (GENERAL PERMITTED DEVELOPMENT) (AMENDMENT) (ENGLAND) ORDER 2015

APPLICATION NUMBER: AWDM/0897/26

Details of Development
TWO STOREY SIDE EXTENSION

Location of Development
1 LISHER ROAD LANCING WEST SUSSEX BN15 9EY

In pursuance of their powers under the above-mentioned Act and Order the Council hereby notify you that they PERMIT the above development, in accordance with the application and relevant correspondence registered on 6th August 2026.

This is for reasons stated on the schedule overleaf and subject to compliance with the conditions specified thereon.

G Peck

Gary Peck
Head of Planning & Development
28/10/2026

Adur District Council, Development Management Place Directorate,
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Tel: 01903 221065 Email: planning@adur-worthing.gov.uk
Web: www.adur-worthing.gov.uk

SCHEDULE

Conditions

01. The development hereby permitted shall be carried out in accordance with the following approved plans unless specified otherwise in a subsequent condition imposed on this decision notice.

Reference/Drawing Number	Version	Date Rec
FLOOD RISK ASSESSMENT	98289 v1.1	23.10.2026
DESIGN AND ACCESS STATEMENT	REV. A	06.08.2026
LOCATION PLAN	289/P/001	06.08.2026
EXISTING AND PROPOSED BLOCK PLANS	289/P/002	06.08.2026
EXISTING GROUND, FIRST FLOOR AND ROOF PLANS	289/P/003	06.08.2026
EXISTING ELEVATIONS	289/P/004	06.08.2026
PROPOSED ELEVATIONS	289/P/011	06.08.2026
LOCAL PRECEDENT LOCATIONS	289/P/012	06.08.2026
FLOOD RISK ASSESSMENT	98289AtelierCon-LisherRd	23.10.2026
PROPOSED GROUND, FIRST FLOOR AND ROOF PLANS	289/P/010 REV A	19.10.2026

Reason: *For the avoidance of doubt and in the interests of proper planning.*

02. The development hereby permitted shall be begun before the expiration of 3 years from the date of this permission.

Reason: *To comply with Section 91 of the Town and Country Planning Act 1990.*

03. The external materials and finishes of the development hereby permitted shall, prior to commencement of use of the additional floorspace thereby created, be completed to match in design, colour and texture those of the existing building unless otherwise approved in writing by the Local Planning Authority.

Reason: *In the interests of visual amenity and to comply with policy 15 of the Adur Local Plan.*

04. The extension hereby approved shall at all times be used as an extension to the original house (1 Lisher Road) to be occupied solely for purposes ancillary to the occupation and enjoyment of the property as a whole (as it exists at the date of this permission) as a single dwellinghouse only. Access to the extension from the hallway and landing as shown on the revised floorplans shall be maintained and kept open at all times. The extension shall not be used as a self contained/separate unit.

Reason: *To enable the Local Planning Authority to maintain strict control over the use of the land in the interest of local character and neighbour amenity and to prevent the creation of a small and under resourced unit of accommodation having regard to Adur Local Plan Policy 15, Development Management Standard No. 1 Space Around New Dwellings and the National Planning Policy Framework.*

05. Prior to commencement of the development, measures to protect or divert the public water supply main shall be submitted in writing to the Local Planning Authority and agreed in consultation with Southern Water. Only such details as agreed shall be implemented prior to any construction.

Reason: *In order to protect public water apparatus in the interest of local amenity having regard to policies 15 and 35 of the Adur Local Plan.*

06. Notwithstanding the provisions of the Town and Country Planning General Permitted Development Order 2015 as amended (or any Order revoking and re-enacting that Order with or without modification), no windows or other openings (other than as hereby approved) shall be formed in the side wall of the extension.

Reason: *To prevent overlooking and to comply with policy 15 of the Adur Local Plan.*

Informatives / Notes to Applicant

01. The Local Planning Authority has acted positively and proactively in determining this application by identifying matters of concern within the application (as originally submitted) and negotiating, with the Applicant, acceptable amendments to the proposal to address those concerns. As a result, the Local Planning Authority has been able to grant planning permission for an acceptable proposal, in accordance with the presumption in favour of sustainable development, as set out within the National Planning Policy Framework.

02. The applicant must follow the drainage hierarchy of preference. Due to the size and location of the development, an infiltration test should be carried out in accordance with the Part H2, paragraph 1.34 to 1.37 of the Building Regulations (https://assets.publishing.service.gov.uk/media/5a80cf9ded915d74e33fc8ae/BR_PDF_AD_H_2015. pdf). This rate should then be put into the calculation in Part H3, paragraph 3.28. Following this the applicant can use the free tools at https://www.uksuds.com/ to size the soakaway for the 1 in 100 (1%) plus CC event.

If infiltration fails, the same links should be used to size attenuation storage to ensure surface water runoff does not increase from the existing discharge rate.
To obtain the relevant rainfall data the applicant can visit https://fehweb.ceh.ac.uk/ to download the point data for their site and input the csv file into the tools above.

03. The applicant must follow the drainage hierarchy of preference. Due to the size and location of the development, an infiltration test should be carried out in accordance with the Part H2, paragraph 1.34 to 1.37 of the Building Regulations (https://assets.publishing.service.gov.uk/media/5a80cf9ded915d74e33fc8ae/BR_PDF_AD_H_2015.pdf). This rate should then be put into the calculation in Part H3, paragraph 3.28. Following this the applicant can use the free tools at https://www.uksuds.com/ to size the soakaway for the 1 in 100 (1%) plus CC event.

    If infiltration fails, the same links should be used to size attenuation storage to ensure surface water runoff does not increase from the existing discharge rate.

    To obtain the relevant rainfall data the applicant can visit https://fehweb.ceh.ac.uk/ to download the point data for their site and input the csv file into the tools above.

04. Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site. The applicant is advised to contact Southern Water Developer Services, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel 0330 303 0119) or www.southernwater.co.uk or email developerservices@southernwater.co.uk

05. Southern Water has requested the imposition of condition 5 as there may be a water mains pipe within 3 metres of the proposed extension. Please refer to: https://www.southernwater.co.uk/media/st5orjvm/stand-off-distances.pdf

Their comments are available to view in full on the Council's website: https://planning.adur-worthing.gov.uk/online-applications/

Ref: AWDM/0897/26

TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (GENERAL PERMITTED DEVELOPMENT) (AMENDMENT) (ENGLAND) ORDER 2015

YOUR ATTENTION IS DIRECTED TO THE FOLLOWING NOTES FROM THE ABOVE ORDER. THEY ARE FOR INFORMATION ONLY AND DO NOT PRETEND TO SET OUT THE WHOLE OF THE LAW ON THE SUBJECT. IT WOULD BE WELL FOR YOU TO CONSULT YOUR SOLICITOR IF YOU ARE IN ANY DOUBT

Appeals to the Secretary of State

1. If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.

2. If the decision relates to a householder application, and you want to appeal, then you must do so within 12 weeks of the date of this notice. If the decision relates to a non-householder application, an appeal must be lodged within 6 months of the date of the decision notice. Appeals must be made using a form which you can get from the Secretary of State at Temple Quay House, 2 The Square, Temple Quay, Bristol BS1 6PN (Tel: 0303 444 5000) or online at https://www.gov.uk/appeal-householder-planning-decision

3. The Secretary of State can allow a longer period for giving notice of an appeal, but he will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

4. The Secretary of State need not consider an appeal if it seems to him that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements to the provisions of any development order and to any directions given under a development order.

5. In practice, the Secretary of State does not refuse to consider appeals solely because the local planning authority based their decision on a direction given by him.

Purchase Notices

6. If either the local planning authority or the Secretary of State refuses permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted. In these circumstances, the owner may serve a purchase notice on the District Council in whose area the land is situated. This notice will require the Council to purchase his interest in the land in accordance with the provisions of Part VI of the Town and Planning Act 1990.

7. Where this notice conveys approval or permission, conditional or unconditional, please note that the decision given does not purport to convey any consent or approval which may be required under the Building Act and Building Regulations, or any other legislation.

Reduced time for making a planning appeal where enforcement action is being taken

Where an enforcement notice has been served on the same, or substantially the same, development as in the householder application within 2 years of the date the application was made, the period for receiving an appeal is within 28 days of the date on the decision notice or of the date by which the LPA should have decided the application. Where an enforcement notice was served after the decision notice was issued or after the end of the period the LPA had to determine the application, the period for receiving an appeal is within 28 days of the date the enforcement notice was served (unless this extends the normal 12 weeks deadline).