Subject: RE: Your ref : DSA000016657

From: Buthee, Neil
Sent: 28 October 2022 14:54
To: southernwaterplanning@southernwater.co.uk
Subject: Your ref : DSA000016657

Ref : Proposal: Condition 12 , 5 commerce way , Lancing business park reference to AWDM/0343/22 Site: AWDM/0343/22: - 5 Commerce Way, Lancing Business Park, Sompting, West Sussex, BN15 8TA

Dear Lucy ,

We are writing in accordance with your letter a copy of which is attached for reference .

Further to our conversation and to clarify the situation we are proposing to seal the Attenuation tank and the permeable paving within 5 metres of the sewer to prevent percolation of the surface water into the ground within the 5m distance as specified in the letter .Please be aware the water table is reasonably shallow in the general vicinity which means your sewers are probably under water .

We trust this satisfies your queries and enables your good selves to remove the objection to the planning officer .

Look forward to your reply

Kind regards

Neil Buthee Bsc(hons), CEng, MIStructE
DIRECTOR

HDR
Bourne House, Prince Edward Street
Berkhamsted, Herts HP4 3EZ
01442 734940
neil.buthee@hdrinc.com

hdrinc.com/follow-us