From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 17 March 2025 13:43:04 UTC+01:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Consultee Comments for Planning Application AWDM/0340/25

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 17/03/2025 12:42 PM from Mr Nadeem Shad (nadeem.shad@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0340/25
Address:	5A Broadwater Street East Worthing West Sussex BN14 9AA
Proposal:	Approval of details reserved by condition 4 (Noise Statement Post Construction Assessment) of application NOTICE/0022/23.
Case Officer:	Louise Prew

Click for further information

Comments Details

Comments:	With reference to the Acoustic report reference: AC20094.02.00 dated March 2025. • The plan makes no reference to the exact location of the internal monitoring position. • It is not clear if windows were open or closed (we presume closed), nor if the ventilation systems were operational at the time. • What is the justification for only one hour being used to calculate the level difference? • The original monitoring data has not been included.

Kind regards