



Adur & Worthing Council
Portland House
44 Richmond Road
Worthing
West Sussex
BN11 1HS

Your ref
NOTICE/0010/26

Our ref
DSA000055722

Date
13th July 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Application for prior approval for proposed change of use of upper floors (Use Class E) to create one self-contained flat (Use Class C3).

Site: 32 Montague Street, Worthing, West Sussex, BN11 3HA.

Thank you for your correspondence, please see our comments below regarding the above application.

Existing Gravity Sewer - tree, buildings, assets within stand-off distance

The 150 mm diameter gravity sewer requires a clearance of 3 metres on either side of the gravity sewer to protect it from construction works and to allow for future maintenance access.

No development or tree planting should be carried out within 3 metres of the external edge of the public gravity sewer without consent from Southern Water. All existing infrastructure should be protected during the course of construction works. Please refer to:

<https://www.southernwater.co.uk/media/st5orjvm/stand-off-distances.pdf>

Condition

In order to protect public sewers, Southern Water requests that if consent is granted, the following condition is attached to the planning permission; The developer must agree with Southern Water, prior to commencement of the development, the measures to be taken to protect the public sewers

Proposed Development located in Flood plain

From the site location, it appears that the proposed development lies within an area identified as flood zone 2/3. Southern Water supports the Government's requirement to apply the sequential and exception tests to development sites located in flood zones 2 or 3. In flood events, additional surface water can inundate sewers, which may result in the overloading of the sewerage system. Southern



Water will rely on the Council's consultations with the Environment Agency to ensure that any proposed development on a floodplain is appropriately assessed, and necessary mitigation measures adopted.

As this site is in a high-risk flood zone the new foul drainage system must be resilient to the flooding as we do not want flood waters to enter the system which would then impede foul drainage from this area and potentially downstream. The developer must ensure the new foul system draining the development does not create a new low spot on the network. If this is a possibility, then consideration should be given to having a pumped connection or other satisfactory mitigation. It appears the area is also prone to high groundwater. The new system must be constructed to withstand high groundwater and should be watertight at pipe joints; within manholes and at ground level. The integrity of the system with respect to water tightness must be demonstrated by air testing.

Condition

In view of the risk of inundation of the proposed drainage system, Southern Water would request that the consent is subject to the following condition: The proposed drainage system shall be designed and constructed to prevent the ingress of flood water into the sewerage network.

S106 Connection application

Any new connections to the public sewerage system will require a Section 106 connection application to be submitted and approved by Southern Water Services.

To make an application visit Southern Water's Get Connected service:

<https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available on our website via the following link:
<https://www.southernwater.co.uk/developing-building/connection-charging-arrangements>

Please note that, where there are separate systems available, Southern Water will not allow surface water to connect into the public foul sewer. If this is not possible, please provide evidence that all other options have been explored.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction work, an investigation of the sewer will be required to ascertain its ownership before any work commences on site. If this happens, please call our Customer Service Desk on 0330 303 0119

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team

southernwater.co.uk/developing-building/planning-your-development