



Elaine Rousseau <elaine.rousseau@adur-worthing.gov.uk>

Fwd: AWDM/0543/26: Air Handling Plant. 56 Montague Street, Worthing

1 message

Support Planning <support.planning@adur-worthing.gov.uk>
To: Elaine Rousseau <elaine.rousseau@adur-worthing.gov.uk>

13 July 2026 at 16:46

----- Forwarded message -----

From: **Michael Lavender** <michael.lavender@adur-worthing.gov.uk>
Date: Tue, 16 Jun 2026 at 13:29
Subject: AWDM/0543/26: Air Handling Plant. 56 Montague Street, Worthing
To: Finlay Gardner <finlay.gardner@adur-worthing.gov.uk>

Hi Finlay,

There are no EH objections in principle.

The acoustic report recommends that the air handling unit be fitted with a silencer. Please can this be conditioned.

Thanks

--

Michael Lavender

Senior Environmental Health Officer
01273 263343
Environmental Health
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

For details on how we handle your data, please see our Privacy Notice.

<https://www.adur-worthing.gov.uk/environmental-health/privacy-notice/>

--

Finlay Gardner

Planning Officer, Planning
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk

