ADUR DISTRICT COUNCIL

U Mehmood
The Joyful Whippet
Steepdown Road
Sompting
West Sussex
BN15 0LJ

TOWN AND COUNTRY PLANNING ACT 1990 (as amended)

APPLICATION NUMBER: AWDM/1421/21

Details of Development
APPLICATION FOR APPROVAL OF DETAILS RESERVED BY CONDITIONS 13 (DRAINAGE) AND 14 (SUDS MAINTENANCE) OF PREVIOUSLY APPROVED AWDM/0998/19.

Location of Development
THE JOYFUL WHIPPET STEEPDOWN ROAD SOMPTING WEST SUSSEX BN15 0LJ

The Authority has considered your application, and I can confirm the following condition(s) have been **APPROVED** subject to satisfactory implementation and in accordance with the approved plans.

G Peck

Gary Peck
Planning Services Manager
15/03/2022

Adur District Council, Development Management, Economy Directorate,
Portland House, 44 Richmond Road, Worthing, West Sussex, BN11 1HS
Tel: 01903 221065 Email: planning@adur-worthing.gov.uk
Web: www.adur-worthing.gov.uk

SCHEDULE

Approved Date - 11/03/2022

13 Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter infiltration testing to BRE DG365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity

Reason: *To ensure adequate drainage and to comply with the National Planning Policy Framework and policy 36 of the Adur Local Plan.*

Approved Date - 11/03/2022

14 Development shall not commence until full details of the maintenance and management of the surface water drainage system is set out in a site-specific maintenance manual and submitted to, and approved in writing, by the Local Planning Authority. The manual is to include details of financial management and arrangements for the replacement of major components at the end of the manufacturer's recommended design life. Upon completed construction of the surface water drainage system, the owner or management company shall strictly adhere to and implement the recommendations contained within the manual.

Reason: *To ensure adequate drainage and to comply with the National Planning Policy Framework and policy 36 of the Adur Local Plan.*

Plans Referred to in Consideration of this application

The application has been assessed and the decision is made on the basis of the following plans and documents submitted:-

Reference/Drawing Number	Version	Date Rec
DRAINAGE DESIGN		27.01.2022
Proposed Drainage Layout	0116-003-P3	27.01.2022
Standard Details	0116-002-P4	27.01.2022