Hydrant condition - AWDM/0640/20 Herons Dale Primary School, Hawkins Crescent, Shoreham-By-Sea, West Sussex, BN43 6TN.

1 message

FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk> 15 May 2020 at 11:59
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>

FAO: Peter Barnett

Dear Mr Barnett,

Please find attached a planning condition for application no. AWDM/0640/20 for the requirement of an additional fire hydrant. Currently the nearest Hydrant to this proposed property is 120 metres away. The supply of water for firefighting for a commercial premises should be within 90 metres. There will also need to be a clear 3.7 metre access for a fire appliance to gain access to the temporary structure, to enable the Fire Appliance to reach all areas of the premises within 45 metres of the appliance (AD-B Volume 2 2019 edition diagram 17.3 page 120).

Regards

Ian Stocks

Water & Access manager

Water and Access Office

West Sussex Fire and Rescue Service West Sussex County Council
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB
Phone: 0330 222 3117 | E-mail: frs.waterandaccess@westsussex.gov.uk

Living Our Values Every Day



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you

in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

Hydrant Condition _ AWDM.0640.20 Herons Dale Primary School, Shoreham-by-Sea BN43 6TN..docx
188K