From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 03 April 2024 09:31:30 UTC+01:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Comments for Planning Application AWDM/0017/24

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 03/04/2024 9:31 AM from Miss Elsie Nunn.

Application Summary

Address:	Office 1 6 Farncombe Road Worthing West Sussex BN11 2BE
Proposal:	New electrical meter kiosk on the south side of the building by the car park at the side of the building
Case Officer:	Rebekah Hincke

Click for further information

Customer Details

Name:	Miss Elsie Nunn
Address:	UK Power Networks, Property and Consents, Bury st Edmunds IP32 7BG

Comments Details

Commenter Type:	Member of the Public
Stance:	Customer made comments neither objecting to or supporting the Planning Application
Reasons for comment:	- Other
Comments:	Please note there are HV and LV cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.

All works should be undertaken with due regard to Health & Safety Guidance notes HS(G)47 Avoiding Danger from Underground services. This document is available from local HSE offices.

Should any diversion works be necessary as a result of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.

Kind regards