From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 19 March 2025 13:25:08 UTC+01:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Consultee Comments for Planning Application AWDM/0012/25

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 19/03/2025 12:24 PM from Mr Nadeem Shad (nadeem.shad@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0012/25
Address:	126 Upper Shoreham Road Shoreham-by-sea West Sussex BN43 6TD
Proposal:	Approval of Details Reserved by Conditions 3 (risk assessment), 5 (CMP), 7 (surface water drainage), 9 (cycle parking), 10 (EV charging), 11 (materials), 12 (fencing) and 13 (refuse storage) of Approved application AWDM/0977/21.
Case Officer:	Eve Hearsey

Click for further information

Comments Details

Comments:	Regarding the CMP we recommend damping down stockpiles of dusty materials to reduce wind whipping and dust issues off site. We await the intrusive site testing report before making comments in relation to potential land contamination.

Kind regards