ADUR & WORTHING
COUNCILS

Technical Services FAO Ken Argent
Adur And Worthing Councils
The Town Hall
Chapel Road
Worthing
BN11 1HA

| | |
|---|---|
| Our reference: | AWDM/0973/19 |
| Please ask for: | Peter Barnett |
| Direct Line: | 01903 221310 |
| Date: | 21st June 2019 |

Approval of Details Reserved by Condition 10 (Surface Water Drainage) of Application Number AWDM/1283/18

8 Fairview Road Lancing West Sussex BN15 0PA

The above planning application was received on 17th June 2019. Please may I have your observations on the above mentioned planning application within the next 21 days.

To view the application please click on the link below or copy and paste into the web browser. Applications can take up to 5 working days to appear.
http://planning.adur-worthing.gov.uk/online-applications/

G Peck

Gary Peck
Planning Services Manager

ADUR & WORTHING
COUNCILS

To: Peter Barnett Application Number: AWDM/0973/19

Proposal: Approval of Details Reserved by Condition 10 (Surface Water Drainage) of Application Number AWDM/1283/18
Location: 8 Fairview Road Lancing West Sussex BN15 0PA

**Observations:**

Peter

I have reviewed the submission which is supplied without calculations to back it up, but the soakaway looks to be the right sort of size. I would be happy to accept the proposal and let building control check the final design.

The only thing that does concern me is the note that says assumed permeable paving, can this be a requirement?

Regards

Ken Argent.

Adur & Worthing Councils, Development Management, Economy Directorate,
Portland House, 44 Richmond Road, Worthing, West Sussex, BN11 1HS
Tel: 01903 221065 Email: planning@adur-worthing.gov.uk
Web: www.adur-worthing.gov.uk