SKH Associates Ltd.

CHARTERED BUILDING SERVICES
Acoustic Consultancy
7 Riseldine Road, London SE23 1JT
Tel: 0208 291 4641
Mob: 07985 484 130
E-mail: salih_Hassan@hotmail.com

CERTIFICATION OF PRE-COMPLETION SOUND INSULATION TESTING

REPORT No: 186 **Date:** 2rd March 2022

Re; 374 Brighton Road, Shoreham, Brighton, BN43 6RE

This is to certify that sound insulation test that was carried out at the above property has successfully meets the minimum requirement defined in table 1a Approved Document E. The tests were carried out in accordance with the requirements of Part E of the building regulation.

Property type: Dwellings – houses and flats formed by material change of use

TEST	Source Room	Receiving Room	Airborne test Measured Dnt,w+ctr	Airborne test Required Dnt,w+ctr	Impact test Measured Lnt,w	Impact test Required Lnt,w	Pass / Fail
1 Floor Test	1/F Flat Lounge	G/F Open plan shop	51	≥50	-	≤64	Pass
2 Floor Test	1/F Flat Lounge	G/F Open plan shop	-	≥50	44	≤64	Pass

Salih K. Hassan
Senior Acoustic Consultant
BSc, BEng (Hons), MSc, MIOA, MIEE, LDip, MSLL, MTCEA, MCIBSE, CEng.
IOA Registration No. 30878
IEE Registration No. 16695640
MCIBSE No 5628
Engineering Council No. 510932