WEST SUSSEX COUNTY COUNCIL CONSULTATION

TO:	Adur & Worthing Councils FAO:Peter Barnett
FROM:	WSCC - Highways Authority
DATE:	6 January 2021
LOCATION:	Adur Dock 104 Albion Street Southwick West Sussex
SUBJECT:	AWDM/2061/20 Application for Approval of Details Reserved by Condition 3 (Construction Method Statement) of previously approved AWDM/1371/20.
DATE OF SITE VISIT:	n/a
RECOMMENDATION:	Advice
S106 CONTRIBUTION TOTAL:	n/a /

For the purposes of this application Condition 3 relates to the sites Construction Method Statement (CMS).

The LHA would be satisfied with the proposed CMS subject to the applicant adhering to the following:

- Schedule site deliveries outside times of peak traffic volume. This should be 08.00-09.00 am and 16.00 to 17.00.
- Ensuring that deliveries to site are kept to their allocated time slots.
- Avoid contractor parking in residential streets surrounding the site.
- All loaded vehicles leaving site must be sheeted.
- Ensure that there are designated walkways on and around site.

Jamie Brown
West Sussex County Council – Planning Services