From: Ken Argent
Sent: 01 February 2019 12:02
To: Peter Barnett
Subject: Re: Planning Application Consultation for 91 Grinstead Lane Lancing West Sussex BN15 9DT

Flag Status: Flagged

Can't accept this peter its partially in fz3 and wholly in flood zone 2

Needs an FRA and a level survey to relate to flood levels.

And needs disposal of surface water to soakaway

I would otherwise have no objections

Ken Argent
Engineer, Adur & Worthing Councils
Phone: 01903221374
Email: ken.argent@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk
Address: Engineering Team, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



On Wed, 30 Jan 2019 at 15:10, <planning@adur-worthing.gov.uk> wrote:

> Please see attached planning consultation