From: Tessa Denny <tessa.denny@adur-worthing.gov.uk>
Sent: 05 August 2024 12:32:51 UTC+01:00
To: "Jo Morin" <jo.morin@adur-worthing.gov.uk>
Subject: AWDM/0669/24 - 191 Tarring Road

Hi Jo,

Please can the following condition be attached to any permission granted in order to protect the residential unit from noise:

- Construction work shall not commence until a scheme for protecting the proposed noise sensitive development from noise from the commercial unit next door has been submitted to and approved by the local planning authority. All works which form part of the scheme shall be completed before tany part of the noise sensitive development is occupied. The scheme shall achieve the Good standard for indoor ambient noise levels for dwellings specified in BS8233:2014 and a minimum airborne sound insulation value of 48dB (DnTw+Ctr dB) for walls. Following approval and completion of the scheme, a test shall be undertaken to demonstrate that the attenuation measures proposed in the scheme are effective and protect the residential unit from noise."

Kind regards

--

Tessa Denny
Environmental Health Technician, Public Health & Regulation
01273 263357
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk



