LEGEND - ENERGY STRATEGY

EV	'Active' EV Charging Point with 5 metre cable distance.
EV	'Active' EV Charging Post
	EV Charging Cable Run (ducted)
	EV Electric Car Charging Cable Tidy/Channel cut into paving slabs.
	Shared Access
G	Gate Locations

Total of **96** 'Active' EV Points proposed on site as per Building Regulations Part S requirement.



Example of an EV Electric Car Charging Cable Tidy/Channel cut into paving slabs.

B	All plots to now have 'active' EV charge points provided (as per Buildings Regs Part S 2023)	02.01.25

REVISIONS

Persimmon

Persimmon Homes (THAMES VALLEY)

Drawing Title

Energy Strategy Plan

Drawing Status

For Construction

Development

West Sompting
Phase 1

Date	Scale	Drawn / Checked by
July/24	1/500@A1P	AT / DD

Drawing Ref	Rev
610_PL_12_Ph1	B