From: planning@adur-worthing.gov.uk
Sent: 16 September 2021 10:58
To: planning@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/1492/21

Flag Status: Flagged

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 16/09/2021 10:58 AM from Mrs Hannah Powell (hannah.powell@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/1492/21
Address:	1 Riverside Southwick West Sussex BN42 4AW
Proposal:	Proposed Change of Use of an office (Use Class B1a) to form 1no. residential unit (Use Class C3) at lower ground floor level.
Case Officer:	Peter Barnett

Click for further information

Comments Details

Comments:	With reference to the above application I have the following comments. Noise The area of development is potentially exposed to elevated levels of road noise and potential noise from surrounding port activities. I would recommend the following condition: Construction work shall not commence until a scheme for protecting the proposed noise sensitive development from external noise has been submitted to and approved by the local planning authority. All works, which form part of the scheme, shall be completed before any part of the noise sensitive development is occupied. The scheme shall have regard to the principles contained within Pro PG: Planning and Noise - Professional Practice Guidance on Planning and Noise - New Residential Development 2017, the World Health Organisation community noise guidelines and achieve the indoor ambient noise levels for dwellings specified in BS8233:2014. The scheme should include full details of glazing and a strategy to prevent overheating. The noise level of any ventilation units when in use should not exceed the levels specified in BS8233:2014 and all duct work should be fitted on anti-vibration mounts. Following approval and completion of the scheme, a test shall be undertaken to demonstrate that the attenuation measures proposed in the scheme are effective and protect the residential unit

from noise.

Contaminated Land
If ground works are proposed I would recommend the following contaminated land condition:

Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the
Local Planning Authority:

(1) A preliminary risk assessment which has identified: all previous uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; and potentially unacceptable risks arising from contamination at the site.

(2) A site investigation scheme, based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.

(3) The site investigation results and the detailed risk assessment (2) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.

(4) A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action. Any changes to these components require the express consent of the Local Planning Authority.

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. It shall also include any plan (a 'long-term monitoring and maintenance plan') for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification plan, and for the reporting of this to the Local Planning Authority.

Asbestos:
The owner(s) of any commercial property (warehouses, offices, etc.) built before 2000 are legally obliged to hold a copy of an asbestos register for each property. As this is being renovated to residential, the Council need to be satisfied that if any asbestos is present, it is either removed or suitably managed to minimise risk to human health as there is no safe threshold for asbestos exposure. A copy of the asbestos register - and any remedial strategy where appropriate – should be provided prior to works commencing.

Kind regards