From: Jo Morin <jo.morin@adur-worthing.gov.uk>
Sent: 11 November 2026 08:19:05 UTC+00:00
To: "Jo Morin" <jo.morin@adur-worthing.gov.uk>
Subject: Fwd: AWDM/1267/26 Blacknest Hall Grand Avenue Worthing

From: **Nadeem Shad** <nadeem.shad@adur-worthing.gov.uk>
Date: Tue, 10 Nov 2026 at 13:35
Subject: Re: AWDM/1267/26 Blacknest Hall Grand Avenue Worthing
To: Jo Morin <jo.morin@adur-worthing.gov.uk>

Hi Jo

The combined noise with both units operating will be 53dBA. As the adjacent property to the east is so close (I make it 2m), this level will not reduce over distance and is therefore likely to adversely affect residential amenity without additional acoustic treatment.

Regards
Nadeem

Nadeem Shad, CEnvH (he/him)
Team Leader Environmental Protection & Animal Welfare
Environmental Health and Licensing
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA.
Tel: 01273 263303

For details on how we handle your data, please see our Privacy Notice.