From: rogersbigtone@aol.com
Sent: 10 March 2020 08:02
To: hannah.barker@adur-worthing.gov.uk
Subject: Re: 46 Victoria Road Southwick AWDM/1289/19

Hannah,

I have sent an e-mail to Laura to say that my client wishes to go green and will be installing a rainwater harvester.

Regards
Tony

-----Original Message-----
From: Hannah Barker <hannah.barker@adur-worthing.gov.uk>
To: rogersbigtone <ROGERSBigtone@aol.com>
Sent: Mon, 9 Mar 2020 10:42
Subject: Fwd: 46 Victoria Road Southwick AWDM/1289/19

Tony,
Please could you provide the details required by Laura.
Thanks
Hannah

Hannah Barker
Senior Planning Officer, Adur & Worthing Councils
Phone: 01903 221475
Email: hannah.barker@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Portland House
Richmond Road
Worthing
West Sussex
BN11 1HH





---------- Forwarded message ---------
From: **Laura Gibbons** <laura.gibbons@adur-worthing.gov.uk>
Date: Mon, 9 Mar 2020 at 09:18
Subject: Re: 46 Victoria Road Southwick AWDM/1289/19
To: Hannah Barker <hannah.barker@adur-worthing.gov.uk>
Cc: rogersbigtone <ROGERSBigtone@aol.com>

Hi Hannah,

The applicant will need to provide testing results, calculations, and a rough plan to evidence that there is sufficient space for surface water drainage.

Kind regards,

On Tue, 3 Mar 2020 at 09:10, Hannah Barker <hannah.barker@adur-worthing.gov.uk> wrote:

> Dear Laura,
>
> Following on from your comments in relation to the above application. There was a previous application AWDM/1687/18 for the redevelopment of this site which was withdrawn pending a redesign. Ken Argent and Tony Rogers (The agent) discussed drainage and concluded below....
>
> "I have discussed this with Ken and we have agreed the soakaway will be situated in the car park and the existing surface water drains into the sewer."
>
> Please can you let me know if this removes your concern and advise accordingly.
>
> I have copied Tony Rogers into this email.
>
> Thank you
>
> Hannah

Hannah Barker
Senior Planning Officer, Adur & Worthing Councils
Phone: 01903 221475
Email: hannah.barker@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Portland House
Richmond Road
Worthing
West Sussex
BN11 1HH





--

Laura Gibbons
Engineer, Adur & Worthing Councils
Phone: 01903 221374
Email: laura.gibbons@adur-worthing.gov.uk
Website: www.adur-worthing.gov.uk
Address: Facilities & Technical Services, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA





This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.